

# Water Supply – Constrained Options Appraisal

SES Water WRMP 2019

SES Water

Project number: 60527524  
60527524-540-Rev6 20180822

22 August 2018

## Quality information

**Prepared by**

---

Travis Kelly  
Principal Hydrogeologist

**Checked by**

---

Jane Sladen  
Technical Director

**Approved by**

---

Jane Sladen  
Technical Director

## Revision History

Revision	Revision date	Details	Authorized	Name	Position
Rev 1	19/07/2017				
Rev 2	25/08/2017				
Rev 3	15/11/2017				
Rev 4	30/11/2017				
Rev 5	31/01/2018				
Rev 6	22/08/2018				

## Distribution List

# Hard Copies	PDF Required	Association / Company Name

Prepared for:

SES Water

Prepared by:

Travis Kelly  
Principal Hydrogeologist

AECOM Infrastructure & Environment UK Limited  
Midpoint  
Alencon Link  
Basingstoke  
Hampshire RG21 7PP  
UK

T: +44(0)1256 310200  
aecom.com

© 2017 AECOM Infrastructure & Environment UK Limited. All Rights Reserved.

This document has been prepared by AECOM Infrastructure & Environment UK Limited ("AECOM") for sole use of our client (the "Client") in accordance with generally accepted consultancy principles, the budget for fees and the terms of reference agreed between AECOM and the Client. Any information provided by third parties and referred to herein has not been checked or verified by AECOM, unless otherwise expressly stated in the document. No third party may rely upon this document without the prior and express written agreement of AECOM.

## Table of Contents

1.	Introduction.....	6
2.	Unconstrained Screening .....	7
2.1	Unconstrained Screening Methodology.....	7
2.2	Unconstrained Option Results .....	7
3.	Constrained Costing Methodology .....	9
3.1	Capital and Operational Costs .....	9
3.2	Social and Environmental Costs .....	10
3.3	Carbon Emissions.....	11
4.	Summary of Supply Side Options .....	12
5.	Summary of Demand Side Options.....	13
5.1	Water Efficiency .....	13
5.2	Metering .....	13
5.3	Leakage .....	14
5.4	Tariffs.....	15
5.5	Summary .....	15
6.	EBSM Modelling.....	16
6.1	Approach.....	16
6.2	Scenario Runs .....	17
6.3	Data Requirements .....	19
6.3.1	Baseline.....	19
6.3.2	Feasible Options .....	19
6.4	Optimisation.....	19
6.4.1	CAPEX .....	20
6.4.2	Fixed OPEX.....	20
6.4.3	Variable OPEX.....	20
6.4.4	Carbon.....	20
6.5	Planning and Assessment Periods.....	21
7.	Conclusions .....	22
8.	References .....	29

## Figures

Figure 1.	Location of sources and constrained options .....	8
Figure 2.	EBSM Model Operation .....	17

## Tables

Table 1.	E&S Qualitative Assessment Scoring Criteria.....	11
Table 2.	Leakage Strategy.....	15
Table 3	Comparison between Bough Beech baseline and climate change scenario deployable output .....	18
Table 4.	EBSM programmes for least cost scenario.....	22
Table 5.	EBSM programmes for environmental scenario.....	24
Table 6.	EBSM programmes for levels of service scenario.....	25
Table 7.	EBSM programmes for stakeholder preferences scenario.....	27
Table 8.	Preferred programme utilising additional stakeholder preferences scenario.....	28

## Appendices

Appendix A Constrained Option Proformas

Appendix B Demand Side Costing

Appendix C EBSD model output

## 1. Introduction

This report describes the methodology adopted in the development of the constrained options for the PR19 Water Resources Management Plan (WRMP), as part of the water resources option appraisal process as set out in the Environment Agency (EA) Water Resources Planning Guideline (WRPG). The constrained options represent those considered feasible from the unconstrained screening process (AECOM, 2017a) and were taken through to a costing process.

The unconstrained list included all options that could help reduce a projected supply-demand deficit over the PR19 planning period, and are a collation of all the concepts and ideas derived from SES Water staff. As specified in the WRPG, all unconstrained options are feasible from an engineering perspective but do not take in account technical, economic or environmental factors and constraints that may affect the viability of implementing an option.

The unconstrained screening process involved a scoring system reflecting the degree of impediment to the scheme with respect to environmental risk, technical feasibility, deliverability and resource supply/savings, to provide a filter for identifying the most favourable options for inclusion on the constrained option list.

The unconstrained screening was presented to the EA during autumn 2016 and a draft report provided, and their views were minuted and included in the unconstrained list option information sheets and added to the report. SES Water then decided to take approximately half of the options per option type to take forward to the constrained stage for costing. That is, a selection of new water resource schemes, plus transfer and bulk supply, as well as treatment schemes were taken forward; the variety of options offering flexibility and resilience for the SES Water network as well as addressing the supply-demand deficit.

The schemes on the constrained options list were developed with outline engineering designs and costing together with the assessment of environmental and social costs. This included an evaluation of the carbon footprint and the carbon costs, and an assessment of potential environmental impacts arising from construction and operation.

Options that could help reduce a projected supply-demand deficit may be supply-side or demand-side measures. This report describes the supply-side options in detail with a summary of demand-side options which are reported in detail separately.

## 2. Unconstrained Screening

The unconstrained screening stage is described in a separate report (AECOM, 2017a). A summary of the methodology and results is given here.

### 2.1 Unconstrained Screening Methodology

The first step includes identifying 'show stoppers' as part of an initial screening phase, which includes liaison with the Environment Agency. Such items include water availability and licensing policy, WFD status and risk of deterioration, and the risk to designated habitats. For options passing the initial screening, the second step assesses each option against further criteria. These related to technical difficulties such as construction impediments, water quality issues, uncertainty as to the yield benefit of the scheme, flexibility and adaptability to future needs, impacts to landscapes and communities, effect on flood risk, and drought resilience.

Each criterion was scored with 1, 2, or 3 representing whether the criteria posed no impediment to the scheme, some issues which could be overcome, or a significant impediment. The rationale for scoring against the criteria was described which varied by option type.

Scores were totalled to give an indication of the overall difficulty of implementing a scheme and its benefits. Different scheme types were compared separately because some criteria were not relevant to certain schemes, which gave them a lower possible score.

### 2.2 Unconstrained Option Results

The process arrived at scored lists for water resource schemes, treatment schemes, and pipeline related transfer and bulk supply schemes. Approximately the top half of each list was selected to form the constrained list to take forward to costing. The list was checked to ensure that it offered a range of options across type and geography to maximise the flexibility of the potential assets.

The SES Water sources and the constrained options are shown in Figure 1.




Figure 1. Location of sources and constrained options

Contains Ordnance Survey Data © Crown Copyright and database right 2016

### 3. Constrained Costing Methodology

The following sections relate to supply-side options.

The constrained options were described in a proforma format with a cost estimate based on the outline engineering designs which assessed the following:

- Option yield (at peak and average),
- CAPEX and OPEX (fixed and variable),
- Social and environmental costs (one off and annual),
- Carbon emitted and carbon costs (one off and annual),
- Estimates of the whole life costs of each option, including capital maintenance,
- A high level assessment of potential environmental impacts during construction and operation,
- An indicative development programme taking into account the need for any further studies and site investigations to aid the scheme design, environmental impact assessments, detailed design, and construction; and
- An understanding of any potential dependencies between options, or options that should only be taken forward if a similar solution is not implemented.

The WRMP process requires Economics of Balancing Supply and Demand (EBSB) costing as per the WRPG which includes the following elements: Capital (CAPEX), Operational (OPEX) fixed and variable, environment and social (E&S) cost, carbon cost, and carbon quantity, for each scheme. There is no specification on how the costing is made in the guidance so the water company must decide what approach is suitable and proportionate for its circumstances.

#### 3.1 Capital and Operational Costs

There are broadly three approaches that can be taken.

1. Itemising costs (typically held by the water company) for each element of an option (e.g. all components related to borehole construction: drilling, steel casing, pumps, electricity, pipeline connection to treatment works etc.), as well as process costs, where all the components to an option have been bundled together (e.g. borehole construction may include drilling and casing and headworks).
2. Itemising costs by contacting various suppliers and building up a cost model from the bottom up, where the water company does not have a current list of items from the contractors they typically engage.
3. Industry standard typical costs. This approach considers typical costs for an item of infrastructure in its entirety from similar construction projects in the water industry. These are generally known from industry experience.

The three approaches involve significantly different degrees of effort. As these schemes are high-level concepts with no detailed design elements, it is generally considered to be inappropriate to attempt to generate itemised costs for each component of the scheme, as this will require a significant number of assumptions that will mean the fine detail of component costs will not correlate with the uncertainty bounds of the final cost. Similarly, a list of component costs from the water company would be applied to a scheme without a detailed design, and therefore results in a cost with low confidence.

In WRMP14 an options costing was derived by SES Water using an industry standard typical costs approach.

The industry standard typical costs approach is considered most appropriate for the purposes of WRMP EBSB modelling, where the intention is to compare total CAPEX and OPEX costs over the lifetime of a scheme's asset to arrive at a least cost investment programme.

Therefore the WRMP costing process is a relatively high-level exercise for comparative purposes to go into EBSD modelling, and is not intended to be a tender specification or final cost for construction of a scheme. Where EBSD modelling identifies a group of schemes that provide the best cost and programme outcomes then it is assumed that these schemes would be the subject of detailed design and tendered or re-evaluated to obtain costs.

For WRMP19, industry standard typical costs were compiled for construction (CAPEX); CAPEX costs tended to cluster around a consistent value with outliers present where schemes were more bespoke. Pipeline and treatment works costs tend towards a consistent cost per metre of pipeline and per volume of flow through treatment. However OPEX costs are more variable with local specific factors. In WRMP14 SES Water compared total business costs to volume of water delivered to estimate OPEX costs and it is understood that there has been no significant change. Therefore the OPEX costs for schemes brought forward from WRMP14 were used and for new schemes an equivalent WRMP14 scheme was used.

## 3.2 Social and Environmental Costs

The aim of the environmental and social (E&S) assessment is to capture and value significant residual impacts (i.e. after mitigation) in relation to the natural environment as well as human impacts on landscape, heritage, business and recreation. The process involved the completion of a qualitative assessment to identify the likely significance of identified impacts, followed by a quantitative assessment.

The E&S costing model is based on established sources used in WRMP with updates, including:

- Benefits Assessment Guidance (BAG) Environment Agency, 2004;
- Water Resource Planning Guideline – The technical methods and instructions. Joint development by Environment Agency, Ofwat, Defra and the Welsh Government, June 2012;
- BAG User Guide, eftec, January 2012;

In WRMP14 most schemes did not have E&S costs as it was demonstrated that there was no significant long term environmental impact. The details and assumptions behind this assessment are not known but this conclusion was accepted by the regulators for the WRMP14.

In WRMP19 it was considered appropriate to undertake a qualitative E&S assessment to understand in more detail the E&S aspects. E&S costs were then quantified using the model described above.

A qualitative ecosystems services appraisal was conducted in the context of the WRPG request to consider using an ecosystem services approach to environmental valuation to help to promote a consistent and integrated approach to environmental valuation across water environment planning. This consistency supports accountability and transparency, and helps with stakeholder engagement.

As with the approach for CAPEX, it was considered proportionate and appropriate for EBSD modelling to use typical E&S costs for similar schemes, rather than input to a calculator for each scheme and carry a set of assumptions leading to uncertainty. E&S costs tend to depend on certain components which are consistent across the water industry. E&S one off costs relate to carbon inputs from construction and whether there is habitat loss. E&S ongoing costs relate to operation of the scheme, which essentially relates to energy use and the derived carbon cost, and if there is a permanent loss to the environment such as a designated habitat site.

Where a water resource scheme removes water from the environment the ongoing costs largely depend on the population density around affected water bodies and habitats, the potential loss of amenity value, and effect on house prices. For schemes with no direct environmental impact, such as a treatment works upgrade where there is no new land take, then the E&S cost is largely associated with carbon costs from operation of the scheme. Therefore E&S costs were derived for each scheme based on option type, volume of flow through the scheme, whether there was a river where flow could be affected, and population density in the vicinity of the river.

The approach taken is considered to reflect the WRPG guidance to use a method that is proportionate to the size of the problem, to use the 'building blocks' approach, making a qualitative, quantitative then monetary assessment if necessary.

As described above, all E&S costs were first assessed qualitatively to identify the scope of anticipated significant residual impacts during construction and operation stages. This process was undertaken by assigning anticipated (post-mitigation) magnitudes to impacts by category on a seven point scale given in Table 1.

**Table 1. E&S Qualitative Assessment Scoring Criteria**

Score	Rating	Definition
+++	Major positive	Significant impact - of national or international importance
++	Moderate positive	Important impact - at regional or local level
+	Minor positive	Small scale impact - at local or regional level
o	Neutral	No overall impacts of significance
X	Minor negative	Small scale impact - at local or regional level
XX	Moderate negative	Important impact - at regional or local level
XXX	Major negative	Significant impact - of national or international importance

Where a significant negative residual impact was described qualitatively, it was carried through into the quantitative assessment. Where no significant negative residual impact was identified, only the carbon cost of operating the scheme would comprise the E&S costs.

Where the only E&S cost was a carbon cost, these were based on industry standard carbon emissions by option type and monetised using the traded and non-traded price for carbon, as provided in DECC guidance.

### 3.3 Carbon Emissions

Carbon emissions, like OPEX, are specific to processes and the local setting. In WRMP14 SES Water estimated carbon emissions using a carbon calculator though the details are not known. It is considered that there has been no significant change as most WRMP14 schemes have been carried forward to WRMP19. For new schemes an equivalent WRMP14 scheme was applied.

The carbon emissions associated with construction are a measure of the carbon embodied in the production of the main materials and items of equipment. An itemised bill of quantities for each scheme would be needed to calculate these emissions. The fixed and variable operational carbon emissions are therefore based on the consumption of energy for pumping and treatment, and the chemicals used relating to each option. These were not recalculated.

The results of the calculator were reported in tonnes of carbon equivalent (tCO<sub>2</sub>e). Carbon dioxide equivalent is used as a representative for comparing the emissions from various greenhouse gases based upon their global warming potential.

As described previously with regard to CAPEX costing, the WRMP process is a relatively high-level exercise for comparative purposes to go into EBSD modelling, and so using these values was considered appropriate for relative comparison of schemes which ultimately provides a carbon cost of a series of potential programmes of measures to address the supply-demand deficit.

Proformas for all constrained options are provided in Appendix A.

## 4. Summary of Supply Side Options

At the commencement of the constrained stage costing it was decided in consultation with SES Water that the option P1c should not be taken forward because the additional treatment works capacity proposed in this option was in excess of demand and the network's capacity to deliver the water. The option R1 to increase Bough Beech capacity was costed to include treatment works upgrades in line with the volume of additional yield this capacity could offer.

The schemes represent a range of option types which offer SES Water resilience and flexibility in meeting demand.

The schemes with the highest CAPEX costs were the Bough Beech reservoir expansion (R1) which is estimated to cost in the order of more than 10 times any other scheme. The Middle Mole abstraction (N6) was the second most expensive requiring more infrastructure inputs than other schemes. The Thames Water bulk supply at Merton (R10) was the next most expensive. All other options were half this cost or cheaper. The cheapest schemes were groundwater schemes at existing sources requiring limited infrastructure works, Outwood Lane (R22) and the Leatherhead Licence Increase (N4).

Fixed operational costs were highest for the Thames Water bulk supply at Merton (R10) which was 2.5 times the cost of the next most expensive scheme, the North Downs Confined Chalk AR extension 1 (Bishopsford Road) (R2). The pipeline linking Pains Hill, Duckpit Wood and Chalk Pit Lane (N8) was the next most expensive. The cheapest schemes were Outwood Lane (R22) and the Leatherhead Licence Increase (N4), New Middle Mole abstraction (N6), New borehole (Mole Valley Chalk) - Fetcham Springs (R5), New Lower Mole Abstraction source (N5).

The Thames Water bulk supply at Merton (R10) has the highest variable operational costs, while most other pipeline transfers and bulk supplies have the lowest variable operational costs, such as the Langley Park/North Looe Reservoirs to Outwood PS variants (R12, R13) and the bulk supply from South East Water (Maidenbower/Whitely Hill) to Outwood PS (R15). The pipeline linking Pains Hill, Duckpit Wood and Chalk Pit Lane (N8), lowering pumps at Kenley and Purley (R28) and Secombe Centre UV (R26) have the next highest costs. Other than the pipeline options the same schemes were cheapest as per fixed operational costs; Outwood Lane (R22) and the Leatherhead Licence Increase (N4), New Middle Mole abstraction (N6), New borehole (Mole Valley Chalk) - Fetcham Springs (R5), New Lower Mole Abstraction source (N5).

E&S one-off costs were highest for options requiring the most infrastructure; the pipeline linking Pains Hill, Duckpit Wood and Chalk Pit Lane (N8), Bough Beech reservoir expansion (R1), and Lowering pumps at Kenley and Purley (R28) which also involves treatment upgrades. The lowest costs are for those schemes with the least infrastructure requirements such as Outwood Lane (R22), the Leatherhead Licence Increase (N4), and North Downs Confined Chalk AR extension 1 (Bishopsford Road) (R2).

E&S ongoing costs are highest for new resource schemes that propose to take more water from the environment in a sensitive location, such as groundwater that provides baseflow to a nearby river. For the list of schemes this applies to those in the Mole catchment (R5, N4, N5 and N6). Although water is available for licensing at certain times of year the E&S calculator considers any change from the current condition to be a potential negative. Costing is largely a function of population density in the area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected. Bough Beech is considered to have a positive ongoing cost (benefit) related to adding habitat. Groundwater schemes where there is little effect on surface waters have the lowest cost such as schemes in the upper Wandle catchment (R22, R28) and schemes in the confined Chalk (R2, R21).

Some options described above were not taken forward to EBSD modelling because they do not carry a yield benefit in themselves, which is required by EBSD in order to solve the supply deficit problem. These schemes are internal pipeline schemes (R12, R13, R12-reverse, R13-reverse) which will improve the capacity of the network to move water from one location to another to meet demand from a range of supply sources. These are resilience options and the screening and outline costing conducted as part of the WRMP screening can be used by SES Water in their business planning.

## 5. Summary of Demand Side Options

This section provides a summary of the costing process for demand-side options. The detail is provided in Appendix B (Artesia, 2018) including references for data sources.

The unconstrained screening stage brought a variety of options through to the constrained stage for costing, including leakage, metering, and efficiency schemes. Tariff and rainwater harvesting schemes were not brought through to the costing stage.

### 5.1 Water Efficiency

The considerations that were applied to the analysis of each of the water efficiency options were:

- The number of households targeted per year is based on a percent of total households; this can be overwritten or varied.
- The length of the programme (in years) is how long the delivery of the option lasts for and can be changed by the modeller.
- Longevity of savings defined as savings that persist for five years after installation, and based on the assumption that products such as tap inserts, low-flow showerheads and cistern displacement devices will remain installed for a relatively short time. An average value of five years has been used to represent this period of time, taking account of the likely period that these products are installed. More durable devices (such as ecoBeta dual flush retrofits) and fixes of leaking toilets will last for a longer period.
- Uptake rate represents the percentage of the properties contacted that choose to take part in the programme.
- Suitability is the percentage of those properties that are suitable and end up receiving part or all of the retrofit. (This may also be affected by other factors such as appointments being met, etc.).
- Unit costs are based on SES Water actual cost where possible.
- The marketing cost varies according to the number of properties involved in the option.

For most of the options, it was assumed that the water savings delivered in each year will persist at that level for a period of 5 years and then revert to zero. Where an option delivers over several years (e.g. more than 5 years) then the year 1 savings endure until year 5, year 2 savings until year 6, etc. This provides a rectangular profile for water efficiency delivery

SES Water has set a target average per capita consumption (PCC) of 135 and 118 l/head/day respectively by 2024-25 and 2049-50. These values refer to a 1 in 10 Dry Year (DY) scenario. To meet the target, SES Water has proposed a suite of water efficiency strategies that include a combination of audit, marketing campaign and water saving products. The assumption used for other water efficiency options were applied for the suite, but costing was supplied by SES Water, while the implementation was modelled to meet the PCC targets. Two versions of this option have been created according to the metering scenario selected in the final plan.

### 5.2 Metering

Meter costs are based on company-specific variables where possible, including meter cost, survey and installation cost, cost of meter reads, and supply pipe repair costs.

The number of properties is obtained from the household demand forecast for the SES water resource zone. The maximum meter penetration is assumed to be 90% of total properties at the end of the forecast period (2080). Compulsory meter for unmeasured households is proposed to be achieved in 10 years.

The saving values for compulsory metering are based on results of metering projects presented in the update to the water efficiency evidence base. Dumb and AMR savings are based on the findings from Southern Water and South East Water. The additional effect of smart metering is based on results from the Anglian Water in-house display project (in the WEFF evidence base report).

For compulsory metering using dumb/AMR meters, we have used evidence from Southern Water (a Southampton University study). The study indicates overall saving, including 'anticipation' effect, of 16.5% for AMR and we have initially used this value as the 'mean water saving'. However, the additional saving obtained through AMR are based on more frequent readings and therefore more regular feedback to the customer. Because SES Water AMR meters are likely to be used as dumb, with no additional readings, the mean estimate is set a 14.5%. This has been agreed with SES Water. The lower estimate of water savings taken from the same study suggests a 13.5% overall reduction in demand and reduced to 11.6% for the same reason. The upper saving of 18.5% reduction in demand is taken from the results of South East Water's metering programme (taken from table 48 of WEFF evidence base report) and reduced to 17.4%.

For the additional effect of smart metering, 5.7 l/prop/d saving was used which is from the Anglian Water in-home display project. This equates to a central value of 1.5% on average unmeasured household consumption. Lower and upper estimates are assumed at 1% and 2% respectively.

Compulsory metering with smart meters is estimated to deliver 18% savings, based on the additional benefit of in-home displays (as per previous analysis). This is considered a conservative estimate, as further savings are likely from data that will be collected, e.g. on leakage, comparative consumption rates and trends in consumption over time. However, this has not been included at present as there are no data to support this.

Selective compulsory metering has been based on the assumption that highest users would reduce their consumption by the same percentages used for the other compulsory metering projects. However, this is unlikely to be the case, since there is insufficient evidence to investigate the potential savings based on household type. It is assumed to target the top 5% water users.

Two enhanced smart metering options have been added in at a later stage of the options process to assess cost and savings for a metering scenario of 80% meter penetration by 2024/25 and 90% by 2029/30, and 90% by 2024/25 and 95% by 2029/30 respectively. For these options, only meter install and maintenance costs for the additional meters were included. The meter read and back office infrastructure costs just for additional meters were included in the costs. Meter replacement is rate assumed to be 15 years.

As for water efficiency options, the marginal cost of water has been considered to determine the value of water saved.

### 5.3 Leakage

Increased find and fix leakage option costing assumes no change in the current ALC process other than a range of increases in manpower resource levels (beyond those required to deliver the short-run SELL) in order to achieve a reduced level of leakage. At some point these may be constrained by policy minimum / background leakage levels.

The scope for new, additional or improved pressure management as an alternative to the current ALC process is assessed by inspection of control point (CP) pressures. CP pressures are compared with an agreed pressure threshold that will ensure that standards of service to customers would not be prejudiced.

Mains renewal options assume different rates of mains renewals based on four scenarios supplied by SES Water.

A single leakage strategy was created for the final plan to ensure consistency with the AMP 7 business plan. The bundle is based on the three leakage options of:

- Increased active leakage control;
- Use of pressure managed areas;
- Mains replacement;

Table 2 shows the percentage reduction in leakage within each of the asset management periods in the planning period.

**Table 2. Leakage Strategy**

	Percentage reduction in leakage within each AMP		
	Active leakage control	Mains renewal	Pressure managed areas
<b>AMP7</b>	5%	5%	5%
<b>AMP8</b>	10%	5%	0%
<b>AMP9</b>	10%	5%	0%
<b>AMP10</b>	10%	5%	0%
<b>AMP11</b>	10%	5%	0%

## 5.4 Tariffs

Tariff options were either screened out of the feasible options list, or not assessed quantitatively, due mainly to lack of data.

However, two versions of the tariff option have subsequently been created to deliver an increasing water saving over time and meet the target PCC set by SES Water. These would be delivered from 2040 onward according to the metering scenario selected in the final plan.

The evidence base in the UK for the impact of tariffs is weak. Delaying this option until this period allows further research to be carried out into tariffs. It also allows time for the existing largely 'dumb' meter stock (and the associated meter data system) to migrate to a more intelligent system over the next 20 years, which in the future we envisage will be more suited to the implementation of innovative tariffs. The details of which specific types of tariffs will be implemented has not been defined, as it will build on the next 20 years of water efficiency and metering installation programmes, and allow the research that will be carried out over that time to lead the decision on which tariffs to use.

## 5.5 Summary

Costing tables for all options and comparison of option types is described in Appendix B.

## 6. EBSD Modelling

### 6.1 Approach

Programme appraisal seeks to find the best way of balancing Supply and Demand from a set of feasible options. The approach being used for SES Water in PR19 is an EBSD (aggregated) approach, similar to the WRSE model used in programme appraisal at a regional level in PR14.

The EBSD model used is highly flexible, and can be customised to suit water companies' needs and has been used for several water company WRMP. This approach of using an existing methodology offers a number of advantages to SES Water, including:

- Tried and trusted;
- Meets regulatory requirements for a schedule of costed investments (Capex/Opex) and utilisation levels (ML/d) for different Planning Scenarios; and
- Same or similar data requirements to what SES Water provided for WRSE.

The model produces a least cost optimised programme of investments over the Planning Period to meet the defined planning challenge. Spatial aggregation is at the level of Water Resource Zones (WRZ).


There are 3 types of decision variables within the formulation:

- Binary: **Which Options** should be selected?
- Integer: **In which year** should the Option be selected / activated?
- Continuous: **What utilisation** should be made of the Option in each year of the Planning Period?

In this context, an Option is any kind of intervention that will either increase available supply or reduce demand to a specific WRZ. The optimal solution will generally consist of multiple options activated in different start years which combine to give the overall least cost solution.

The key input data for the model defines both the planning challenge, and the range of potential solutions to that challenge at the aggregated level of WRZ. All the modelling uses an annual time step. Different planning conditions that may arise within year are accounted for by using planning scenarios - Dry Year Annual Average (DYAA) and Dry Year Critical Period (DYCP).

The diagram below provides a high-level view of the model operation.



**Figure 2. EBSD Model Operation**

The optimisation routine finds the combination of decisions which together minimise the discounted cost of the investment programme whilst ensuring a supply-demand balance in both Dry Year Annual Average and Dry Year Critical Period.

A high-level assumption is required to be made regarding the relative proportions of DYAA to DYCP within the dry year in order to estimate the overall variable operating costs within a year.

The discounted costs are found using a function called Net Present Value (NPV); this computation converts future cash flows to a present-day value. It applies a progressively greater discount to costs incurred in future years. Thus, costs incurred far into the future are most heavily discounted. This encourages the model to delay expenditure in the optimised plan.

## 6.2 Scenario Runs

The EBSD model was run for numerous scenario types. Runs evolved in some instances in an iterative way; that is, the outcome of the previous run raised questions as to why the model selected or did not select certain options, or decided to implement them at certain times. And in other instances runs were created in a way to force the model to discriminate against certain options to see what it would select instead.

This iterative approach allowed SES Water to understand the drivers behind the modelling outcomes, such as costs, time frames for implementation of an option, and the yield benefit in the context of the rising demand profile with time.

An Environmental run was undertaken by 'forcing' the model not to select certain options. WFD screening, SEA screening, and discussions around sustainable catchments with the EA identified that three options (R22, R28, R8) were in catchments flagged by the EA as potentially requiring measures to achieve Good status or could put future status at risk. The EA advice was that these options could be taken forward because they were not Category 1 or 2 meaning that impacts were predicted for long into the future but the scenario was run to test what the model would select if these options were not available, to compare with other model runs.

Levels of service scenario runs were conducted to test resilience by increasing demand and making the same options available to close the deficit. These were called levels of service runs.

An additional scenario was created following consultation with stakeholders. Stakeholders expressed a preference for demand management rather than new supply options (AECOM, 2017b). These runs were designed to exclude supply options that the two sets of stakeholder groups independently decided were not desirable, leaving a smaller selection of supply options with all demand options available to the model. This approach meant that the model was not being forced to choose any particular demand or supply option, but was

run to find a solution to the supply-demand deficit with a suite of option that included mostly demand management options.

Further stakeholder runs were made utilising the preferences described above plus compulsory smart metering of selected households and mains renewal as well as runs including a greater penetration of smart metering.

Each scenario was run under the worst drought in the historic record (WDHR) and a hypothetical 1 in 200 year drought. These scenario runs would enable SES Water to decide on the best programme of measures to suit their business from the range of programmes generated by EBSD modelling.

A final set of scenario runs were conducted in order to test how the influence of climate change on Bough Beech deployable output impacts the EBSD modelling. This was only run under the 1 in 200 scenario since this is where there was some concern with regards to the influence of climate change on Bough Beech deployable output (AECOM, 2017c), and hence the overall outputs of the EBSD model.

The baseline deployable output for Bough Beech (with no impact of climate change) and the deployable output from the average climate model are given in Table 3. It shows that the average climate change model increases DO by 4.6 MI/d (DYCP) and 3.8 MI/d (DYAA) as a result of wetter winters enabling more water to be abstracted to fill the reservoir.

To test the sensitivity of EBSD model outputs to Bough Beech DO changes as a result of climate change, two runs were completed:

- the climate change effects on Bough Beech were removed whilst the average climate change effects on groundwater were retained; and
- the minimum climate change effects were applied to Bough Beech with the average climate change effects on groundwater retained. This reduced DO for Bough Beech from the baseline by 2.3 MI/d (DYCP) and 1.9 MI/d (DYAA).

**Table 3 Comparison between Bough Beech baseline and climate change scenario deployable output**

Scenario	1:200 year DYCP	1:200 year DYAA
Baseline	21.5	17.8
Average climate change model	26.1	21.6
Sensitivity to climate change Run 1 climate change removed	21.5	17.8
Sensitivity to climate change Run 2 minimum climate change effects	19.2	15.9

The new Bough Beech DO combined with groundwater DOs was input to the EBSD model to test whether a different set of options would be selected to solve the supply-demand deficit. The EBSD model selected the same options as it did in the original runs. This can be expected because the reduction in overall DO as a result of reductions at Bough Beech is small, up to approximately 3% of the water available for use.

Therefore the effect of some climate models increasing DO at Bough Beech is considered to be negligible in terms of the overall water available for supply and the selection of options in the EBSD model.

## 6.3 Data Requirements

### 6.3.1 Baseline

The baseline supply / demand balance (SDB) is developed to predict a future position with no new investment. It quantifies the size of any deficit in any WRZ on an annual basis. This defines the planning challenge to be solved by the EBSD optimisation.

The SDB is defined as:

**Deployable output** - the amount of water that can reliably be provided by an existing source

*Minus* **Climate change impacts** - expected impacts on future deployable output

*Minus* Known Sustainability reductions

*Minus* **Outage and process losses** - expected impacts of non-availability of water supply assets

*Minus* **Water demand** - amount of potable water meet customer demand and leakage

*Minus* **Target headroom** - the allowance for uncertainty in the forecasted supply and demand.

Estimates have been developed for these components in both Dry Year Annual Average (DYAA) and Dry Year Critical Period (DYCP).

The baseline included transfers between SES Water and other water companies that are already in operation or were planned based on WRSE modelling. The volumes involved were varied where required based on water company discussions. In particular SES Water transfer to South East Water at River Hill was changed from a constant 5 MI/d, to 2.5 MI/d for the WDHR annual average and 10 MI/d for the critical period. For the 1 in 200 scenario, the transfer volume was set to 2.25 MI/d annual average and 9 MI/d for the critical period. This has been aligned to the SEW revised draft WRMP with a start date put back to 2042.

### 6.3.2 Feasible Options

The EBSD model formulation is designed to ensure that different types of options can be appraised within the same framework. The options presented to the EBSD model are deemed to be feasible.

The types of data required for each option are:

- Monetised Costs
- Impact on SDB
- Timing Constraints
- Interdependency Constraints

A range of options have been developed which will contribute to reducing the forecast deficit in one of the four identified WRZ. These include a mix of option types.

## 6.4 Optimisation

The objective of the model is to find the set of decisions (which Options, which Start Year, what utilisation) which minimise the total discounted cost whilst maintaining a supply demand balance in all zones throughout the planning period.

There are 3 cost types which the model is able to consider:

- Capex – initial and renewals
- Opex – fixed and variable

- Monetised Carbon

Solution costs will always be calculated for each of these three elements, however the user can choose to exclude one or two of these elements from the cost function to be minimised on a particular optimisation model run. This may be helpful to understand whether the solution is sensitive in this respect, e.g. does the inclusion / exclusion of Carbon costs affect the model decision.

#### 6.4.1 CAPEX

Capex expenditure may be of two types, initial capex associated with acquiring an asset, and renewals capex incurred periodically throughout the asset life.

Within the EBSD model, there is an important pre-processing step where all the identified Capex expenditure for an option is used to create a single Annuity Capex value. It is this Annuity Capex value which the model will use to find the optimised solution. The Annuity Capex value is applied in each year for a selected option from the first year of activation.

Calculating an Annuity Capex value is a way of avoiding biases which might otherwise stem from Assets/Interventions which have very different lives, or which have capital expenditure incurred over different lead times.

#### 6.4.2 Fixed OPEX

Fixed Opex refers to those operating costs which are incurred for an Option regardless of the yield benefit level. This may be constant over time (generally this is the assumption for supply options) or there could be a profile of Fixed Opex costs over time. The model uses the Fixed Opex in a similar way to the Annuity Capex, it will be applied in each year for a selected option from the first year of activation.

#### 6.4.3 Variable OPEX

Variable Opex (Vopex) refers to those operating costs which are related to the yield benefit level of the Option (in ML/d). The Unit Cost per ML/d needs to form an input for each Option. The total Vopex over a year is found from multiplying this Unit Cost by the utilisation in ML/d.

The model anticipates that different utilisations for the same Option, in a single year may feature in the optimal programme. For example, a higher utilisation level in DYCP planning conditions to that in DYAA planning conditions may be optimal.

Therefore, the Annual Vopex for an option are computed as follows by adding DYAA and DYCP Vopex costs, applying a weighting to represent the proportion of time in each.

Weighted Variable Opex for a Year =

Unit Cost (£k per ML/d) x Utilisation ML/d in DYAA x % of period which is DYAA

+

Unit Cost (£k per ML/d) x Utilisation ML/d in DYCP x % of period which is DYCP

The unit cost (£k per ML/d) is a model input for each Option. The ML/d utilisation of an option within the optimised programme is a decision variable, and part of the modelling outputs.

#### 6.4.4 Carbon

Carbon created in the Option is input in tonnes of CO<sub>2</sub>, which is then monetised through the use of a carbon calculation module within the model. This module takes into account a profile of future increasing carbon costs to produce a monetised figure which forms part of the objective cost function.

## 6.5 Planning and Assessment Periods

Within the model there are two different time windows used - the Planning period and the Assessment period. These are partially user-configurable in length.

The model works by minimising the overall costs for the *assessment period* in the most economic way to meet the supply demand balance in the *planning period*

For PR19, the necessary planning period is 25 years, 2020 to 2044. SESW are undertaking model runs for a planning period of 60 years, i.e. 2020 to 2079.

The *assessment period* is the number of years of costs that the model takes into account in the calculation of a particular solution's NPV. This will be either equal to or longer than the planning period.

A longer assessment period is recommended, and the SESW model is set up to use an 80-year assessment period although this is configurable. The assessment period should be of the same order as the asset life of the longest Option.

This is because in annualising the Capex costs, the Capex is effectively spread over the asset life. Taking a longer cost assessment period avoids a risk of bias in selecting an expensive scheme in the later years of the planning period when this is reflecting only a small proportion of the capital outlay. The initial capex of a scheme is being spread over the asset life to produce an annuitised cost so this effect will be most pronounced on assets with long lives.

Extending the assessment period beyond the period for which the model is solving the planning problem addresses this potential bias in the model. It requires an assumption of what the future utilisations and related variable operating costs will be. This is done by extrapolating the utilisation and costs in the final year of the planning period for the length of the assessment period.

## 7. Conclusions

The options selected by the EBSD model under each scenario are given below. The year of delivery is when the option becomes available to the EBSD model to draw water depending on demand, in the most cost effective way from amongst the range of options available in the scenario. Depending on operational costs the model will decide whether to use an option considering the amount of water required compared to other available water sources. The utilisation refers to whether the option, once available, was used in the model run period.

The least cost option involved implementing demand side measures until the 2050s when new supplies would be required to meet the supply-demand deficit. This was achieved through mains renewal, pressure management to reduce leakage, and smart metering of selected households. Supply side options were the Outwood Lane pump capacity increase, Leatherhead licence increase, and new borehole at Fetcham Springs scheme. In the 2060s new demand options selected are additional leakage reduction, a variable infrastructure charge, and household works such as leaking toilets and toilet retrofit, with the new Lower Mole abstraction source an additional supply option.

The options selected in each scenario are given in Table 4 below.

**Table 4. EBSD programmes for least cost scenario**

Least Cost WDHR		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399a: Mains renewal_a	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	Y
SESW-MET-311: Smart metering of selected households	2046	Y
SESW-NGW-R22: Outwood Lane	2051	Y
SESW-NGW-N4: Leatherhead licence increase	2055	N
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2058	N
SESW-LEA-302b: Improve RM efficiency_b	2063	Y
SESW-LEA-301a: Improve ALC efficiency_a	2063	Y
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2063	Y
SESW-WEF-307: Variable infrastructure charge	2065	Y
SESW-WEF-157: Dual flush toilets retrofit	2065	Y
SESW-NGW-N5: New Lower Mole Abstraction source	2068	N
SESW-LEA-073f: Increased ALC effort_f	2075	Y
SESW-WEF-022: Non HH WEF company led self install	2075	Y
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	Y

Least Cost 1 in 200		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399a: Mains renewal_a	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	Y
SESW-NGW-N4: Leatherhead licence increase	2049	Y
SESW-NGW-R22: Outwood Lane	2052	Y
SESW-LEA-302a: Improve RM efficiency_a	2055	Y
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2057	N
SESW-LEA-301a: Improve ALC efficiency_a	2063	Y
SESW-WEF-307: Variable infrastructure charge	2065	Y
SESW-WEF-157: Dual flush toilets retrofit	2065	Y
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	Y
SESW-NGW-N5: New Lower Mole Abstraction source	2068	N
SESW-WEF-022: Non HH WEF company led self install	2075	Y
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	Y

For the 1 in 200 year drought variant the Leatherhead licence increase supply option was selected by the model six years earlier with Outwood Lane being selected one year later, such that overall more new supply is available to meet the demand.

The environmental runs resolved the supply-demand deficit in a very similar way to the least cost scenario because the options excluded from the environmental runs did not include two of the selected supply options in the least cost run. That is, compared to the least cost run the environmental run needed to find a different source to Outwood Lane. This was achieved with the New Lower Mole supply option entering service after 2059 and some alternative demand management options.

For the 1 in 200 year drought variant the model resolved the supply demand deficit in a similar way to the least cost scenario again, by bringing forward supply options. Leatherhead licence increase supply option and new borehole at Fetcham Springs were both selected one year earlier.

The options selected in each scenario are given in Table 5 below.

**Table 5. EBSD programmes for environmental scenario**

Environmental WDHR		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399a: Mains renewal_a	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	Y
SESW-NGW-N4: Leatherhead licence increase	2050	Y
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2053	N
SESW-NGW-N5: New Lower Mole Abstraction source	2059	N
SESW-WEF-022: Non HH WEF company led self install	2064	Y
SESW-LEA-073g: Increased ALC effort_g	2065	Y
SESW-LEA-301a: Improve ALC efficiency_a	2065	Y
SESW-WEF-157: Dual flush toilets retrofit	2065	Y
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	Y
SESW-LEA-073c: Increased ALC effort_c	2067	Y
SESW-LEA-073f: Increased ALC effort_f	2075	Y
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	Y
SESW-LEA-302a: Improve RM efficiency_a	2077	Y
Environmental 1 in 200		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399a: Mains renewal_a	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	N
SESW-NGW-N4: Leatherhead licence increase	2049	Y
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2052	N
SESW-LEA-302a: Improve RM efficiency_a	2057	Y
SESW-NGW-N5: New Lower Mole Abstraction source	2059	N
SESW-WEF-307: Variable infrastructure charge	2065	Y
SESW-WEF-157: Dual flush toilets retrofit	2065	Y
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	Y
SESW-LEA-073g: Increased ALC effort_g	2066	Y
SESW-LEA-301a: Improve ALC efficiency_a	2068	Y
SESW-LEA-073f: Increased ALC effort_f	2075	Y

The levels of service runs were at least four times more costly than the environmental runs. The model selected mains renewal and pressure management to reduce leakage in the 2020s and then in the 2040s brought in the three supply options used in the least cost runs. In the 2040s demand options are also required: smart metering of selected households and non-household retrofits. In the 2050s further leakage reduction options are selected and a variable infrastructure charge with a new supply source available in 2060, the new Lower Mole source.

For the 1 in 200 year drought variant the supply options are each selected two years earlier. The new Lower Mole source is brought into supply four years earlier in 2056. Other demand and supply options change only marginally.

The options selected in each scenario are given in Table 6 below.

**Table 6. EBSD programmes for levels of service scenario**

Levels of Service WDHR		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399a: Mains renewal_a	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	Y
SESW-NGW-R22: Outwood Lane	2042	Y
SESW-WEF-022: Non HH WEF company led self install	2044	Y
SESW-MET-311: Smart metering of selected households	2045	Y
SESW-NGW-N4: Leatherhead licence increase	2046	Y
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2049	Y
SESW-LEA-302c: Improve RM efficiency_c	2053	Y
SESW-LEA-301b: Improve ALC efficiency_b	2054	Y
SESW-LEA-073f: Increased ALC effort_f	2055	Y
SESW-WEF-307: Variable infrastructure charge	2058	Y
SESW-NGW-N5: New Lower Mole Abstraction source	2060	Y
SESW-LEA-073g: Increased ALC effort_g	2064	Y
SESW-LEA-073c: Increased ALC effort_c	2065	Y
SESW-WEF-157: Dual flush toilets retrofit	2065	Y
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	Y
SESW-NGW-R28: Lowering pumps at Kenley and Purley	2074	N
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	Y

---

 Levels of Service 1 in 200
 

---

Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399a: Mains renewal_a	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	Y
SESW-NGW-R22: Outwood Lane	2040	Y
SESW-NGW-N4: Leatherhead licence increase	2044	Y
SESW-MET-311: Smart metering of selected households	2046	Y
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2047	Y
SESW-LEA-301a: Improve ALC efficiency_a	2051	Y
SESW-LEA-302c: Improve RM efficiency_c	2054	Y
SESW-NGW-N5: New Lower Mole Abstraction source	2056	Y
SESW-LEA-073g: Increased ALC effort_g	2062	Y
SESW-LEA-073f: Increased ALC effort_f	2062	Y
SESW-WEF-307: Variable infrastructure charge	2065	Y
SESW-WEF-157: Dual flush toilets retrofit	2065	Y
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	Y
SESW-NGW-R28: Lowering pumps at Kenley and Purley	2072	N
SESW-WEF-022: Non HH WEF company led self install	2075	Y
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	Y

The stakeholder options excluded numerous supply side options and made certain demand management options mandatory. This scenario was more expensive than the least cost and environmental runs, and are up to three times more expensive than the levels of service runs.

This scenario selected the same demand side options selected in the least cost runs however with a different mains renewal plan. With stakeholders excluded several supply side options, Outwood Lane was not implemented as in the least cost scenario, with the new Lower Mole source being brought forward four years. Smart metering of selected households is implemented in 2021 instead of 2046 to account for the loss of available supply options to choose from.

For the 1 in 200 year drought variant additional efficiency measures are implemented in the 2060s to reduce demand, which allows the Kenley and Purley supply option to be no longer required.

The options selected in each scenario are given in Table 7 below.

**Table 7. EBSD programmes for stakeholder preferences scenario**

Stakeholder WDHR		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399d: Mains renewal_d	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	Y
SESW-MET-311: Smart metering of selected households	2021	Y
SESW-NGW-N4: Leatherhead licence increase	2055	Y
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2057	Y
SESW-NGW-N5: New Lower Mole Abstraction source	2064	Y
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	Y
SESW-LEA-302c: Improve RM efficiency_c	2070	Y
SESW-WEF-307: Variable infrastructure charge	2070	Y
SESW-NGW-R28: Lowering pumps at Kenley and Purley	2072	N
SESW-WEF-022: Non HH WEF company led self install	2075	Y
SESW-WEF-021: Household WEF programme partnering approach home visit	2075	Y
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	Y
Stakeholder 1 in 200		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-399d: Mains renewal_d	2021	Y
SESW-LEA-303: Enhanced pressure management	2021	Y
SESW-MET-311: Smart metering of selected households	2021	Y
SESW-NGW-N4: Leatherhead licence increase	2054	Y
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2057	N
SESW-LEA-302b: Improve RM efficiency_b	2063	Y
SESW-NGW-N5: New Lower Mole Abstraction source	2065	N
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	Y
SESW-WEF-307: Variable infrastructure charge	2071	Y
SESW-LEA-301a: Improve ALC efficiency_a	2073	Y
SESW-WEF-022: Non HH WEF company led self install	2075	Y
SESW-WEF-021: Household WEF programme partnering approach home visit	2075	Y
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	Y

SES Water expressed their preference for the stakeholder scenario above compared to the other scenarios and so this was taken forward for additional runs implementing further penetration of smart metering and an export related to the identification during WRSE modelling of a transfer to South East Water, which would be operable from 2042 at 2.5 MI/d for the WDHR annual average and 10 MI/d for the critical period. For the 1 in 200 scenario, the transfer volume will be 2.25 MI/d annual average and 9 MI/d for the critical period. These runs sought to maximise the demand-side options in order to minimise or eliminate the need for new supply-side options.

This stakeholder scenario represented SES Water's preferred plan. The preferred plan is given in Table 8 which involves demand-side solutions only. The EBSD model chose the same options for both the WDHR and the 1:200 drought.

The supply-side options identified in the options appraisal process and selected in some of the EBSD model scenarios described above remain as the preferred supply-side options when these become necessary, hence these represent resilience options for the current planning period. These are a new borehole at the Fetcham Springs source (R5), a licence increase at the Leatherhead source (N4), a new source in the lower Mole valley a short distance downstream of Leatherhead (N5), and a pipeline and treatment works to connect sources at Chalk Pit Lane, Pains Hill and Duckpit Wood to Godstone and Westwood treatment works (N8).

**Table 8. Preferred programme utilising additional stakeholder preferences scenario**

Final Plan WDHR		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-900: Leakage Strategy 1	2020	Y
SESW-WEF-700b-ph1: Water Efficiency PR19 Option 1b (phase 1)	2020	Y
SESW-MET-600: Compulsory metering AMI - enhanced higher meter penetration	2020	Y
SESW-TAR-800b: Tariffs (scenario b)	2045	Y
SESW-WEF-700b-ph2: Water Efficiency PR19 Option 1b (phase 2)	2045	Y

Final Plan 1 in 200		
Option	Year Delivered	Option Utilised (Y/N)
SESW-LEA-900: Leakage Strategy 1	2020	Y
SESW-WEF-700b-ph1: Water Efficiency PR19 Option 1b (phase 1)	2020	Y
SESW-MET-600: Compulsory metering AMI - enhanced higher meter penetration	2020	Y
SESW-TAR-800b: Tariffs (scenario b)	2045	Y
SESW-WEF-700b-ph2: Water Efficiency PR19 Option 1b (phase 2)	2045	Y

The preferred plan and resilience options were then subject to a strategic environmental assessment and Habitats Regulations Assessment which is described separately (AECOM, 2018a and AECOM, 2018b).

These selected options have been determined to be the best given a range of criteria and modelling described in this report. Prior to implementation a detailed feasibility study would be undertaken for each option to give detail to the potential environmental impacts and confirm the suitability of the scheme or refinements to the scheme.

EBSD model summary outputs are given in Appendix C.

## 8. References

AECOM, 2017a. SES Water Draft Water Resources Management Plan 2019. Options Appraisal Supply-Side.

AECOM, 2017b. Water Supply – Constrained Options Appraisal. Stakeholder Engagement Report.

AECOM, 2017c. Water Supply – Deployable Output and Climate Change Impact Assessment Report.


AECOM, 2018a. SES Water Draft Water Resources Management Plan 2019. Strategic Environmental Assessment (SEA). Environment Report.

AECOM, 2018b. SES Water Draft Water Resources Management Plan 2019. Habitats Regulations Assessment (HRA).


Artesia, 2018. WRMP19 Demand Management Options – Assessment of Feasible Demand Management Options.

## Appendix A Constrained Options Proformas

Name	Leatherhead licence increase	
Code	N4	
Description	Scheme to increase licence by 2 Mld to take water available at least 50% of the time in CAMS policy. Treat at Elmer WTW as per existing source where there is existing capacity.	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	0	Additional licensable water available for half the year so assume not available for peak period use.
Peak Lower Limit of Max Utilisation	0	Additional licensable water available for half the year so assume not available for peak period use.
Average Upper Limit of Max Utilisation	2	Maximum quantity available for licensing
Average Lower Limit of Max Utilisation	1	Lower possible bound of yield and borehole capacity
Earliest Start Year	2020	Assumed at start of next cycle
Construction period (years)	1	Assume 1 year for replacement or modification of pumps and licensing
Capex (£)	30000	Cost based on typical industry standard costs for pump replacement/enhancement only so at lower end of cost range.
Fixed Opex (£/yr)	2000	Cost based on typical costs for similar schemes in WRMP14. eg R5, reduced due to low pumping rate
Variable Opex (p/m3)	13	Cost based on typical costs for similar schemes in WRMP14. eg R5, R22, R28
E&S One-Off (£)	3000	Typical value for groundwater scheme used from E&S costing calculator at low end of range due to limited infrastructure requirements and no additional treatment. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	200,000	Typical value for groundwater scheme used from E&S costing calculator for proximity to stream with minor effects. Cost largely a function of population density in area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected.
Carbon One-Off (tCO2e)	19.9	Estimate based on similar scheme from 2014.
Carbon Fixed (tCO2e / year)	n/a	Estimate based on similar scheme from 2014.
Carbon Variable (tCO2e / Ml)	0.000000798	Estimate based on similar scheme from 2014.
Min Cost Down (%)	10	Based on complexity of scheme
Max Cost Uplift (%)	10	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.




Name	New Lower Mole Abstraction source	
Code	N5	
Description	<p>Water availability in CAMS at least 50% of the time below Leatherhead. Scheme is to identify new source location for groundwater abstraction from the Chalk or surface water abstraction (or river terrace gravels). Pipeline required for treatment at Elmer WTW where there is existing capacity. Depending on land access can be as short a pipeline distance as possible once down gradient of CAMS assessment point at Leatherhead.</p> <p>Using this source for the 50% of water availability reduces the ADO on other sources which means they can be increased above current ADO when in use to meet existing annual licence.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	0	Additional water in CAMS only available for half the year so likely to exclude the peak period.
Peak Lower Limit of Max Utilisation	0	Likely yield based on historic rates at Leatherhead and Fetcham
Average Upper Limit of Max Utilisation	17	Maximum quantity available for licensing. This is only available for half the year.
Average Lower Limit of Max Utilisation	10	Likely yield based on historic rates at Leatherhead and Fetcham. For EBSD purposes use 5 Mld to reflect that 10 MLd could be yielded for half the year only.
Earliest Start Year	2020	Assumed at start of next cycle
Construction period (years)	3	Assume 3 years for drilling, testing, licensing and connection to network
Capex (£)	3,500,000	<p>Cost based on typical industry standard costs for borehole with associated pipeline WRMP options appraisal. Involves borehole construction and not just pump replacement or refurbishment, and short distance pipeline, so at lower end of cost range for full boreholes schemes plus pipelines.</p> <p>Connection to local raw water main at Leatherhead boreholes approximately 400m away, based on SESW land owned downstream of Leatherhead gauging station, where water taken to Elmer WTW for treatment where there is existing capacity.</p>
Fixed Opex (£/yr)	2900	Cost based on WRMP14 cost for drilling new borehole at Fetcham (R5)
Variable Opex (p/m3)	13.38	Cost based on WRMP14 cost for drilling new borehole at Fetcham (R5)
E&S One-Off (£)	5000 + 1000 = 6000	Typical value for groundwater with pipeline scheme from E&S costing calculator. Typical pipeline cost per metre and borehole without additional treatment requirements. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	200,000	Typical value for groundwater scheme used from E&S costing calculator for proximity to stream with minor effects. Cost largely a function of population density in area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected.
Carbon One-Off (tCO2e)	589.9	As per similar scheme from 2014 assessment (i.e. R5 and R6)
Carbon Fixed (tCO2e / year)	n/a	As per similar scheme from 2014 assessment (i.e. R5 and R6)
Carbon Variable (tCO2e / Ml)	6.885E-07	As per similar scheme from 2014 assessment (i.e. R5 and R6)
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	



Name	New Middle Mole Abstraction source	
Code	N6	
Description	<p>Water availability in CAMS at least 50% of the time in Dorking area. Scheme is to identify new source location for groundwater abstraction from the Lower Greensand or surface water abstraction along the River Mole east of Dorking.</p> <p>Existing Dorking Lower Greensand abstraction delivered to Elmer WTW for treatment, so can use existing infrastructure to add additional source. Alternatively additional volume could be delivered via a new pipe connection to Headley Reservoir or Buckland Booster to deliver it to the Buckland area and north toward Croydon where there is greater demand, improving network resilience.</p> <p>Using this source for the 50% of water availability reduces the ADO on other sources which means they can be increased above current ADO when in use to meet existing annual licence.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	40	Maximum quantity available for licensing dependent on whether scheme also used at average and hence remaining water available at peak
Peak Lower Limit of Max Utilisation	10	Lower possible bound of yield and borehole capacity
Average Upper Limit of Max Utilisation	40	Maximum quantity available for licensing
Average Lower Limit of Max Utilisation	10	Lower possible bound of yield and borehole capacity
Earliest Start Year	2020	Assumed at start of next cycle
Construction period (years)	3	Assume 3 years for drilling, testing, licensing and connection to network
Capex (£)	£10,000,000	<p>Cost based on typical industry standard costs for borehole with associated pipeline WRMP options appraisal. Involves borehole construction and not just pump replacement or refurbishment so at upper end of cost range.</p> <p>Connection to local raw water main approximately 7km dependent on siting where water taken to Elmer WTW for treatment where there is existing capacity.</p> <p>Standard borehole design and pump installations.</p>
Fixed Opex (£/yr)	2900	Cost based on WRMP14 for similar scheme at Fetcham (R5)
Variable Opex (p/m3)	13.38	Cost based on WRMP14 for similar scheme at Fetcham (R5)
E&S One-Off (£)	5000 + 14,000 = 19,000	Typical value for groundwater with pipeline scheme from E&S costing calculator. Typical pipeline cost per metre and borehole without additional treatment requirements. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	200,000	Typical value for groundwater scheme used from E&S costing calculator for proximity to stream with minor effects. Cost largely a function of population density in area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected.
Carbon One-Off (tCO2e)	589.9	As per similar scheme from 2014 assessment (i.e. R5 and R6)
Carbon Fixed (tCO2e / year)	n/a	As per similar scheme from 2014 assessment (i.e. R5 and R6)
Carbon Variable (tCO2e / Ml)	6.885E-07	As per similar scheme from 2014 assessment (i.e. R5 and R6)
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.




WRMP19 Options Appraisal


Name	Pipeline linking Pains Hill, Duckpit Wood and Chalk Pit Lane to existing treatment works at Westwood and Godstone	
Code	N8	
Description	<p>Pipeline linking Pains Hill, Duckpit Wood and Chalk Pit Lane to existing treatment works at Westwood and Godstone (alternative to R24 and R25). Making use of existing spare capacity at Godstone WTW.</p> <p>Includes the construction of one pumping station and approximately 12km of pipework through suburban and rural roads and fields. Assumed +300mm diameter</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	5.54	Maximum designed benefit
Peak Lower Limit of Max Utilisation	1	Assumed risk of lower abstraction in drier years
Average Upper Limit of Max Utilisation	4.77	Maximum designed benefit
Average Lower Limit of Max Utilisation	1	Assumed risk of lower abstraction in drier years
Earliest Start Year	2020	Assumed start of next cycle
Construction period (years)	10	Assume 10 years for design, permissions, construction
Capex (£)	3,000,000 + 1,300,000 = 4,300,000	Cost based on typical industry standard costs for construction of approximately 12km of below ground pipework. Plus cost of additional treatments works at Pains Hill and Duckpit Wood (2.14 Mld) at typical industry cost of £600k per Mld.
Fixed Opex (£/yr)	30,050 + 18,000 = 48,050	<p>New option requiring assessment based on equivalence with WRMP14 costed options. No clear equivalence by length of pipeline, column pumped or terrain. R15 WRMP14 values used as a mid range cost.</p> <p>Scheme incorporates WRMP14 schemes for treatment options so same values used (average of both schemes).</p>
Variable Opex (p/m3)	6.03 + 20 = 26	<p>New option requiring assessment based on equivalence with WRMP14 costed options. No clear equivalence by length of pipeline, column pumped or terrain. R15 values used as a mid range cost.</p> <p>Scheme incorporates WRMP14 schemes for treatment options so same values used (average of both schemes).</p>
E&S One-Off (£)	500,000 + 41,000 = 541,000	<p>Typical value for pipeline scheme from E&amp;S costing calculator. Middle of range requiring pumping stations and pipeline. Cost largely a function of CAPEX related carbon costs.</p> <p>Typical value for treatment works used from E&amp;S costing calculator per Mld (2.14 Mld). Cost largely a function of CAPEX related carbon costs. £19,000 per Mld.</p>
E&S Annual (£/year)	24,000 + 6,300 = 30,300	<p>Based on typical costs from E&amp;S calculator for pipeline schemes. Costs largely a function of pumping across distance carbon costs at typically £2/metre. Assumes no loss of priority habitat or stream ecology impacts by careful routing.</p> <p>Typical value for treatment scheme used from E&amp;S costing calculator for site that does not reduce priority habitats. Cost largely a function of carbon operational running costs. Typically £3000 per Mld.</p>
Carbon One-Off (tCO <sub>2</sub> e)	3040 + 277 = 3317	Based on WRMP14 costing for R2, scaled up for pipeline length. Treatment works as per WRMP14.
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	
Carbon Variable (tCO <sub>2</sub> e/Ml)	0.00000805 + 0.00000107 = 0.0000092	Based on WRMP14 costing for R2, scaled up for pipeline length. Treatment works as per WRMP14 average ongoing cost for combined schemes.
Min Cost Down (%)	50	Based on uncertainty around WRMP14 costing rationale
Max Cost Uplift (%)	50	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.




Name	Raising of Bough Beech reservoir	
Code	R1	
Description	<p>Raising the Bough Beech reservoir embankment would increase the volume of stored water, which would provide an increase in the average yield from the reservoir. This option has been included to demonstrate the costs and likely increases in average yield from such a scheme. Based on available drawings of the earth dam alignment, a 3m raising of the embankment would appear to be feasible. It is likely that some realignment of the embankment locally to the small housing development on the north side of the embankment would be required. A detailed study would be necessary to confirm the viability of this scheme.</p> <p>A 3m raising of the embankment would increase the storage volume of the reservoir by approximately 3,600Ml. The Aquator model of the Bough Beech reservoir system was used to estimate the additional average yield created by the dam raising. It is estimated that the scheme would provide an additional annual average yield of 5.5Ml/d, but no increase in peak output which is constrained by the WTW capacity.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	0	Average scheme only
Peak Lower Limit of Max Utilisation	0	Average scheme only
Average Upper Limit of Max Utilisation	4.9	Maximum designed benefit
Average Lower Limit of Max Utilisation	2	Assumed risk of lower abstraction in drier years
Earliest Start Year	2020	Assumed start of next cycle
Construction period (years)	10	Assume 10 years for design, permissions, construction
Capex (£)	150,000,000	Cost based on typical industry standard costs for reservoirs. Including embankment, pipework and treatment upgrades. Similar to WRMP14 estimate.
Fixed Opex (£/yr)	31,940	As per 2014 assessment.
Variable Opex (p/m3)	14.52	As per 2014 assessment.
E&S One-Off (£)	500,000	Typical costs from E&S calculator. E&S one-off costs associated with carbon emissions from construction. Assumed to include storage structure plus treatment and pipework upgrades.
E&S Annual (£/year)	-46700	As per 2014 assessment. Note that E&S impacts are anticipated to be positive.
Carbon One-Off (tCO <sub>2</sub> e)	9074.00	As per 2014 assessment.
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment.
Carbon Variable (tCO <sub>2</sub> e/ML)	0.000000584	As per 2014 assessment.
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.




Name	North Downs Confined Chalk AR extension 1 (Bishopsford Road)	
Code	R2	
Description	<p>Bishopsford Rd borehole was drilled and constructed in 2008. This scheme connects the borehole into the Cheam WTW East Main at Goatbridge. The objective of the scheme is to increase the PDO of the licence group by allowing recovery of the artificially recharged volume at Hackbridge at a higher abstraction rate over a shorter period of time during the subsequent peak demand period. In order to realise this 5 Ml/d increase in PDO, a licence variation would be required allowing a 5 Ml/d increase in the daily licence from 19 Ml/d to 24 Ml/d.</p> <p>This scheme connects the existing licensed borehole into the WTW A East Main at Source. Estimated approximately 1.2km pipeworks for 600mm pipe as coordinates are not immediately available.</p>	
Dependencies		
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	5	Anticipated yield.
Peak Lower Limit of Max Utilisation	3	Assumed lower end of likely yield
Average Upper Limit of Max Utilisation	0	Peak scheme only
Average Lower Limit of Max Utilisation	0	Peak scheme only
Earliest Start Year	2020	Assumed start of next cycle
Construction period (years)	3	
Capex (£)	640,000	Cost based on typical industry standard costs for pipeline construction
Fixed Opex (£/yr)	54400	As per 2014 assessment
Variable Opex (p/m3)	14.22	As per 2014 assessment
E&S One-Off (£)	2,000	Typical value for transfer scheme from E&S costing calculator. Typical pipeline cost per metre without associated treatment requirements. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	2,400	Based on typical costs from E&S calculator for pipeline schemes. Costs largely a function of pumping across distance carbon costs at typically £2/metre. Assumes no loss of priority habitat or stream ecology impacts by careful routing.
Carbon One-Off (tCO <sub>2</sub> e)	304	As per 2014 assessment
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment
Carbon Variable (tCO <sub>2</sub> e/MI)	0.000000805	As per 2014 assessment
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	



Reproduced from Ordnance Survey digital map data  
 © Crown copyright 2017. All rights reserved. Licence number 0100031673.




Name	New borehole (Mole Valley Chalk) - Fetcham Springs	
Code	R5	
Description	<p>The PDO of the Fetcham Spring/Boreholes source could potentially be increased by 3.148M/d to the peak licence by the installation of new boreholes which would allow abstraction above the current potential yield of the source. The scheme comprises the installation of a collector well and radiating horizontal boreholes to intercept natural springflow and minimising drawdown thereby reducing the environmental impact on natural groundwater flow to the River Mole.</p> <p>Potential for an ADO scheme based on licence usage, assuming works described above enable additional yield to be abstracted. Fetcham springs averages 8.516 Mld compared to a licensed daily rate 13.675 Mld. Data from 2010-16 indicates that the licence offers 4.78 Mld on average if borehole can be made to yield.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	3.148	Maximum quantity available for licensing
Peak Lower Limit of Max Utilisation	2	Lower possible bound of yield and borehole capacity
Average Upper Limit of Max Utilisation	4.78	Maximum quantity available for licensing
Average Lower Limit of Max Utilisation	2	Lower possible bound of yield and borehole capacity
Earliest Start Year	2020	Assumed at start of next cycle
Construction period (years)	3	Assume 3 years for drilling, testing, licensing and connection to network
Capex (£)	2,000,000	<p>Cost based on typical industry standard costs for borehole WRMP options appraisal. Involves borehole construction and not just pump replacement or refurbishment so at upper end of cost range.</p> <p>Connection to local main only at short distance where water taken to Elmer WTW for treatment where there is existing capacity.</p> <p>Standard borehole design and pump installations.</p>
Fixed Opex (£/yr)	2900	As per 2014 assessment.
Variable Opex (p/m3)	13.38	As per 2014 assessment.
E&S One-Off (£)	5000	Typical value for groundwater scheme used from E&S costing calculator at middle of range related to borehole infrastructure with only limited pipeline requirements and no additional treatment. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	200,000	Typical value for groundwater scheme used from E&S costing calculator for proximity to stream with minor effects. Cost largely a function of population density in area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected.
Carbon One-Off (tCO <sub>2</sub> e)	351.5	As per 2014 assessment
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment
Carbon Variable (tCO <sub>2</sub> e/MI)	0.000000607	As per 2014 assessment
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.


Additional boreholes to increase abstraction at existing Fetcham site




Name	Upgrade WTW (Lower Greensand) - The Clears ammonia and pesticide treatment	
Code	R8	
Description	<p>The Cliftons Lane Licence Group (Cliftons Lane, Buckland and The Clears) ADO is constrained by combination of DAPWL (Cliftons Lane) and water quality (Buckland) but is only 1.6 Ml/d short of licence based on difference between daily average licence and abstraction returns from 2010-2016, so little scope for significant increase in ADO.</p> <p>The Group PDO is constrained by combination of DAPWL (Cliftons Lane - base of the confining layer) and water quality (Buckland) and is 2.57Ml/d short of group licence.</p> <p>PDO could potentially be increased by 2.57Ml/d by provision of ammonia treatment at The Clears (or possibly Buckland) to allow pumping reintroduction of the source (or pumping beyond the operational guideline of 1.4Ml/d at Buckland). This scheme is therefore to provide ammonia removal plant (ion exchange with zeolite) and GAC adsorbers (for residual pesticides) on site at The Clears. The anticipated ADO gain is 0.38 Ml/d and the PDO gain is 2.57 Ml/d.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	2.57	Maximum estimated benefit
Peak Lower Limit of Max Utilisation	2.57	Based on WTW design full benefit anticipated
Average Upper Limit of Max Utilisation	0.38	Maximum estimated benefit
Average Lower Limit of Max Utilisation	0.38	Based on WTW design full benefit anticipated
Earliest Start Year	2020	Assumed start of next cycle
Construction period (years)	3	Assume 3 years for WTW design, permissions, construction
Capex (£)	1,500,000	Cost based on typical industry standard costs for treatment works upgrades for Mld capacity. (£600k per Mld used).
Fixed Opex (£/yr)	25,000	As per 2014 assessment.
Variable Opex (p/m3)	18.2	As per 2014 assessment.
E&S One-Off (£)	48,830	Typical value for treatment works used from E&S costing calculator per Mld. Cost largely a function of CAPEX related carbon costs. £19,000 per Mld.
E&S Annual (£/year)	7,710	Typical value for treatment scheme used from E&S costing calculator for site that does not reduce priority habitats. Cost largely a function of carbon operational running costs. Typically £3000 per Mld.
Carbon One-Off (tCO <sub>2</sub> e)	410.20	As per 2014 assessment.
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment.
Carbon Variable (tCO <sub>2</sub> e/Ml)	0.000000792	As per 2014 assessment.
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.




Name	15M/d bulk supply from Thames Water (London WRZ) to SESW at Merton	
Code	R10	
Description	<p>This option involves the same infrastructure components as the 30M/d transfer scheme, but each component is instead sized to accommodate a 15M/d bulk transfer from Thames Water's London ring main into the north of SESW at Merton. The scheme comprises a new pumping station at Merton, significant mains upgrade works to transport water from Merton to Cheam WTW, where it will require additional softening at a new ion exchange softening plant before being blended with the other water treated at Cheam and distributed throughout the SESW area. Two new distribution mains will then also be required to transport the water from Cheam WTW to SESW's North Looe and Langley Park service reservoirs, for onward distribution throughout the network. This scheme is mutually exclusive with the other two size variants of this option.</p> <p>This option includes 14km pipework running from Merton to North Looe Reservoir via Langley Park, a medium size pumping station for 15M/d transfer. The price includes a softening plant, however, consideration of the feasibility for introducing this feature is recommended.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	15	Design capacity
Peak Lower Limit of Max Utilisation	15	Assume capacity can be met from a variety of sources
Average Upper Limit of Max Utilisation	15	Design capacity
Average Lower Limit of Max Utilisation	15	Assume capacity can be met from a variety of sources
Earliest Start Year	2020	Assumed start of next cycle
Construction period (years)	10	Assume 10 years for design, permissions, construction
Capex (£)	7,600,000	Cost based on typical industry standard costs for construction of four pumping stations to transport 12M/d and approximately 14km below ground pipework.
Fixed Opex (£/yr)	131,150	As per WRMP14 assessment
Variable Opex (p/m3)	85.15	As per WRMP14 assessment
E&S One-Off (£)	212,000	As per WRMP14 assessment
E&S Annual (£/year)	28,000	Based on typical costs from E&S calculator for pipeline schemes. Costs largely a function of pumping across distance carbon costs at typically £2/metre. Assumes no loss of priority habitat or stream ecology impacts by careful routing.
Carbon One-Off (tCO <sub>2</sub> e)	2092	As per WRMP14 assessment
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per WRMP14 assessment
Carbon Variable (tCO <sub>2</sub> e/ML)	0.00000049	As per WRMP14 assessment
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Reproduced from Ordnance Survey digital map data  
 © Crown copyright 2017. All rights reserved. Licence number 0100031673.





Name	10MI/d bulk supply from SEW RZ2 (Maidenbower/Whitely Hill) to Outwood PS	
Code	R15	
Description	<p>This option involves a 10MI/d bulk supply from South East Water's (SEW's) RZ2 at Whitely Hill into SESW at Outwood. A new pumping station would be required at Whitely Hill, a new treated water transfer main to transport water north to Outwood, and a new softening plant at Outwood to soften the water prior to distribution throughout the network. This variant of the option is not mutually exclusive with the 5MI/d option, i.e. there could be in total a 15MI/d transfer.</p> <p>Includes the construction of a pumping station and approximately 14km pipework via an outlined route via fields and rural roads to transport 10MI/d. Softening plant preliminary costings included, however, it is strongly advised a feasibility study of the requirements for softening plant infrastructure is undertaken.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	10	Design capacity
Peak Lower Limit of Max Utilisation	10	Assume capacity can be met from a variety of sources
Average Upper Limit of Max Utilisation	10	Design capacity
Average Lower Limit of Max Utilisation	10	Assume capacity can be met from a variety of sources
Earliest Start Year	2020	Assumed start of next cycle
Construction period (years)	10	Assume 10 years for design, permissions, construction
Capex (£)	3,400,000	Cost based on typical industry standard costs for construction of one pumping station, softening plant, and approximately 14km below ground pipeworks to transport 10MI/d.
Fixed Opex (£/yr)	30,050	As per 2014 assessment
Variable Opex (p/m3)	6.03	As per 2014 assessment
E&S One-Off (£)	30,000	Typical costs for pipeline scheme from E&S costing calculator per metre. Softening not considered to carry significant cost compared to typical treatments.
E&S Annual (£/year)	28,000	Based on typical costs from E&S calculator for pipeline schemes. Costs largely a function of pumping across distance carbon costs at typically £2/metre. Assumes no loss of priority habitat or stream ecology impacts by careful routing.
Carbon One-Off (tCO <sub>2</sub> e)	468.7	As per 2014 assessment
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment
Carbon Variable (tCO <sub>2</sub> e/MI)	0.000000297	As per 2014 assessment
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.




Name	North Downs Confined Chalk AR extension 2 (new borehole on SE side of Football Club)	
Code	R21	
Description	<p>The scheme comprises the drilling of another borehole approximately halfway between Goatbridge and Bishopsford Road boreholes. Subject to a licence variation, this borehole would allow recovery of the water that has been artificially recharged at Hackbridge between November and March at a higher rate and over a shorter period of time than is currently possible. This would effectively increase the PDO by an assumed 5M/d to allow the Company to address increases in peak demand from Cheam over the summer months. The annual licence would remain unchanged.</p> <p>Potential for an ADO scheme has been considered by comparing the Cheam group daily average licence limit with abstraction returns for the group from 2010-2016. The group licence offers an average headroom of 2.16 Mld. If this quantity was taken from Cheam and discharged at the Hackbridge discharge borehole then this could offer average use as well as peak.</p>	
Dependencies	This scheme is contingent on the Bishopsford Road borehole scheme (R2) being implemented first as it is effectively an extension of that scheme and assumes that it would tap into a new main running to Bishopsford Rd.	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	5	Maximum estimated benefit
Peak Lower Limit of Max Utilisation	2	Minimum likely yield
Average Upper Limit of Max Utilisation	2.16	Headroom available on existing licence
Average Lower Limit of Max Utilisation	2	Minimum likely yield
Earliest Start Year	2025	Assumed after completion of R2
Construction period (years)	2	Assume 2 years for borehole construction and connection to network, and licence change
Capex (£)	2,000,000	<p>Cost based on typical industry standard costs for borehole WRMP options appraisal. Involves borehole construction and not just pump replacement or refurbishment so at upper end of cost range.</p> <p>Connection to local main only at approximately 0.5km distance to connect to main Bishopsford Road to Goatbridge.</p> <p>Standard borehole design and pump installations.</p>
Fixed Opex (£/yr)	8310	As per 2014 assessment
Variable Opex (p/m3)	14.22	As per 2014 assessment
E&S One-Off (£)	5000 + 1000 = 6000	Typical value for groundwater with pipeline scheme from E&S costing calculator. Typical pipeline cost per metre and borehole without additional treatment requirements. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	2,000	Typical value for groundwater scheme used from E&S costing calculator for distant from stream with minor effects. Cost largely a function of population density in area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected. In this case little measureable effect on ecology so impact is carbon related.
Carbon One-Off (tCO <sub>2</sub> e)	216.1	As per 2014 assessment
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment
Carbon Variable (tCO <sub>2</sub> e/ML)	0.00000805	As per 2014 assessment
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Name	Outwood Lane	
Code	R22	
Description	<p>This scheme seeks an increase in daily licence from 3 Ml/d to 8 Ml/d and requires an equivalent increase in pump capacity. The hydraulic capacity of the source has been proved during previous test pumping. The increase in PDO associated with the scheme would be 5 Ml/d.</p> <p>Potential for an ADO scheme has been considered by comparing the Woodmansterne group daily average licence limit with abstraction returns for the group from 2010-2016. The group licence offers an average headroom of 3.4 Mld if the borehole can be made to yield it.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	5	Maximum proven yield
Peak Lower Limit of Max Utilisation	5	Proven yield
Average Upper Limit of Max Utilisation	3.4	Headroom available on existing licence
Average Lower Limit of Max Utilisation	3.4	Headroom available on existing licence
Earliest Start Year	2020	Assumed at start of next cycle
Construction period (years)	1	Assume 1 year for replacement or modification of pumps and licensing
Capex (£)	30000	Cost based on typical industry standard costs for pump replacement/enhancement only so at lower end of cost range.
Fixed Opex (£/yr)	4580	As per 2014 assessment.
Variable Opex (p/m3)	12.7	As per 2014 assessment.
E&S One-Off (£)	3000	Typical value for groundwater scheme used from E&S costing calculator at low end of range due to limited infrastructure requirements and no additional treatment. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	2,000	Typical value for groundwater scheme used from E&S costing calculator for distant from stream with minor effects. Cost largely a function of population density in area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected. In this case little measureable effect on ecology so impact is carbon related.
Carbon One-Off (tCO <sub>2</sub> e)	19.9	As per 2014 assessment.
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment.
Carbon Variable (tCO <sub>2</sub> e/ML)	0.000000798	As per 2014 assessment.
Min Cost Down (%)	20	Based on complexity of scheme
Max Cost Uplift (%)	20	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.




Name	Secombe Centre UV	
Code	R26	
Description	This scheme provides UV treatment for the Secombe Centre groundwater source which is currently out of supply due to bacti detections on the raw water. Due to the limited footprint available at the Secombe Centre site, the UV treatment plant would be located at Cheam WTW on the 'East Main' which feeds water from Hackbridge, Goatbridge, Woodcote, Oaks, Langley Park, Sutton and Sutton Court Rd boreholes as well as Secombe Centre. Although the PDO of Secombe Centre is only 4.54 ML/d, the daily licence for the East Main sources is 66 ML/d and so the plant would need to have this capacity. This would provide pre-emptive protection against any further bacti or cryptosporidium detections at other sources on the main. The anticipated increase in ADO is 2.07 ML/d (= 3.9 ADO of source - 1.53 that could be reassigned to Cheam and 0.3 to Sutton Court Rd) and in PDO is 4.54 ML/d.	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	4.54	Maximum estimated benefit
Peak Lower Limit of Max Utilisation	4.54	Based on WTW design full benefit anticipated
Average Upper Limit of Max Utilisation	2.07	Maximum estimated benefit
Average Lower Limit of Max Utilisation	2.07	Based on WTW design full benefit anticipated
Earliest Start Year	2020	Assumed start of next cycle
Construction period (years)	3	Assume 3 years for WTW design, permissions, construction
Capex (£)	3,000,000	Cost based on typical industry standard costs for treatment works upgrades for MLd capacity (£600k per Mld used).
Fixed Opex (£/yr)	17,400	As per 2014 assessment
Variable Opex (p/m3)	25.23	As per 2014 assessment
E&S One-Off (£)	86,260	Typical value for treatment works used from E&S costing calculator per Mld. Cost largely a function of CAPEX related carbon costs. £19,000 per Mld.
E&S Annual (£/year)	13,620	Typical value for treatment scheme used from E&S costing calculator for site that does not reduce priority habitats. Cost largely a function of carbon operational running costs. Typically £3000 per Mld.
Carbon One-Off (tCO <sub>2</sub> e)	575	As per 2014 assessment
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment
Carbon Variable (tCO <sub>2</sub> e/ML)	0.000001292	As per 2014 assessment
Min Cost Down (%)	30	Based on complexity of scheme
Max Cost Uplift (%)	30	




Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.



Name	Lowering pumps at Kenley and Purley	
Code	R28	
Description	<p>Increase Kenley PDO from 18 Ml/d by 6 Ml/d to 24 Ml/d by lowering pump and pump cutout in Borehole No. 1 by 2m. Increase Purley PDO from 6.9 Ml/d by 8.5 Ml/d to 15.4 Ml/d by lowering pump and pump cutout in Borehole Nos. 5, 6 &amp; 7 by approximately 15m</p> <p>Potential for ADO scheme has been considered looking at average usage at the group licence boreholes, Kenley and Purley. However there is uncertainty in the data sources regarding headroom available.</p> <p>These licences aggregated and giving an average licence headroom of 4.77 MLd. However also an additional aggregation to Smitham which is in the Woodmansterne Group. Woodmansterne Group has an average headroom of 3.4 Mld. However uncertain whether this licence information is correct and whether additional Kenley &amp; Purley abstraction can only be up to the licence limit of the lowest of Kenley &amp; Purley and Woodmansterne or Kenley &amp; Purley only. Conservative estimate used here.</p>	
Dependencies	None	
	Value	Assumptions
Maximum Utilisation (ML/d)		
Peak Upper Limit of Max Utilisation	14.5	Maximum quantity available for licensing dependent on whether scheme also used at average and hence remaining water available at peak
Peak Lower Limit of Max Utilisation	5	Lower possible bound of yield and borehole capacity
Average Upper Limit of Max Utilisation	3.4	Headroom available on existing licence
Average Lower Limit of Max Utilisation	3.4	Headroom available on existing licence
Earliest Start Year	2020	Assumed at start of next cycle
Construction period (years)	1	Assume 1 year for replacement or modification of pumps and licensing
Capex (£)	30,000 + 2,040,000 = 2,070,000	Cost based on typical industry standard costs for pump replacement/enhancement only so at lower end of cost range.  Costs for UV treatment at Kenley treatment works due to increasing microbial detections and increasing yield at this source increases its criticality to supply. Therefore additional treatment to insure against outage. Costs based on typical industry costs at an average of £600k per Mld. Average yield benefit used.
Fixed Opex (£/yr)	24,540 + 17,400 = 41,940	As per 2014 assessment for borehole works, plus additional treatment works opex using Secombe Centre UV as approximate equivalent per Mld.
Variable Opex (p/m3)	12.67 + 25.23 = 37.90	As per 2014 assessment for borehole works, plus additional treatment works opex using Secombe Centre UV as approximate equivalent per Mld.
E&S One-Off (£)	3000 + 275,500 = 278,500	Typical value for groundwater scheme used from E&S costing calculator at upper end of range; though limited infrastructure but additional treatment requirements. Treatment costs typically £19k per Mld. Cost largely a function of CAPEX related carbon costs.
E&S Annual (£/year)	2,000	Typical value for groundwater scheme used from E&S costing calculator for distant from stream with minor effects. Cost largely a function of population density in area of potentially affected ecology, whether waterfront properties are present and house prices may be affected, and whether river bank-side recreation is affected. In this case little measureable effect on ecology so impact is carbon related.
Carbon One-Off (tCO <sub>2</sub> e)	92.8	As per 2014 assessment.
Carbon Fixed (tCO <sub>2</sub> e/year)	N/A	As per 2014 assessment.
Carbon Variable (tCO <sub>2</sub> e/Ml)	0.000000797	As per 2014 assessment.
Min Cost Down (%)	20	Based on complexity of scheme
Max Cost Uplift (%)	20	



Reproduced from Ordnance Survey digital map data  
© Crown copyright 2017. All rights reserved. Licence number 0100031673.



## Appendix B Demand Side Costing

SES Water

WRMP19 demand management options –  
Assessment of Feasible Demand Management  
Options

AR1181

August 2018

Report title: WRMP19 demand management options – Assessment of Feasible Demand Management Options

Report number: AR1181

Date: August 2018

Client: SES Water

Author(s): Daniele Di Fiore  
Dene Marshallsay  
Rob Lawson

The contents of this document are subject to copyright and all rights are reserved. No part of this document may be reproduced, stored in a retrieval system or transmitted, in any form or by any means electronic, mechanical, photocopying, recording or otherwise, without the prior written consent of the copyright owner. This document has been produced by Artesia Consulting Ltd.

Any enquiries relating to this report should be referred to the authors at the following address:

Artesia Consulting Ltd, Unit 2 Badminton Court, Yate, Station Road, Bristol, BS37 5HZ.

Telephone: + 44 (0) 1454 320091

Website: [www.artesia-consulting.co.uk](http://www.artesia-consulting.co.uk)

## Executive Summary

This report complements the report regarding unconstrained option identification and screening that have been produced to investigate demand management strategies for SES Water resource zone. In particular, it details the approach and assumptions that Artesia have used to evaluate cost and benefits of feasible demand management strategies identified in previous stages.

The report details:

- Classification of feasible options that have been assessed quantitatively;
- Description and rationale of why some option have been assessed qualitatively only;
- Detailed assumptions regarding savings and costs for water efficiency, metering and leakage options;
- Assumptions around the evaluation of carbon costs;
- Required information that needs to be outputted into the 'Economics of Balancing supply and Demand' (EBSD) workbook that has been produced by decisionLab and will be used to screen options as indicated by the EBSD requirements.

The aforementioned EBSD workbook is supplied together with this document.

## Contents

1	Introduction .....	3
1.1	Structure of this report .....	3
2	Feasible options list .....	4
2.1	Options not assessed quantitatively .....	5
3	Costs and savings of feasible water efficiency and metering options .....	9
3.1	Water efficiency.....	9
3.2	Metering projects.....	15
4	Costs and savings of feasible leakage options .....	18
4.1	Leakage options.....	18
5	Bundled options.....	21
5.1	PR19 option 1 (700a & 700b) .....	22
5.2	Tariffs (800a & 800b) .....	24
5.3	Bundle scenarios.....	25
5.4	Leakage bundle.....	26
6	Carbon Cost .....	27
7	Summary of results .....	29
8	EBSB Workbook output .....	31

## Figures

Figure 1	PCC target against draft final plan .....	21
Figure 2	PCC target against proposed strategies.....	23
Figure 3	PCC target against proposed strategies and introduction of tariffs.....	25

## Tables

Table 1	Feasible option list .....	4
Table 2	Cost of water efficiency options .....	11
Table 3	Water efficiency option savings .....	12
Table 4	Variable infrastructure charge uptake scenarios .....	15
Table 5	Variable infrastructure charge cost (loss of revenue) and saving .....	15
Table 6	Metering option Costs .....	17
Table 7	Metering option Savings .....	17
Table 8	Metering Option 555 Costs .....	18
Table 9	PMA scheme types .....	19
Table 10	Leakage – Increasing ALC effort costs .....	19
Table 11	Mains renewal scenarios.....	20
Table 12	Mains renewal costs.....	20
Table 13	SES Water - Option PR19 1 cost and saving .....	22
Table 14	Water saving for each tariff option in PCC (l/head/day) .....	24
Table 15	Bundle 1 .....	25
Table 16	Bundle 2.....	26
Table 17	Leakage bundle .....	27
Table 18	Carbon weights and costs .....	27
Table 19	Carbon assumptions travel and materials .....	27
Table 20	Summary of AIC and savings for feasible options (over 25 years planning period) .....	29

# 1 Introduction

This document details the analysis of demand side options that were selected as feasible options during the initial option screening process, including leakage, water efficiency, metering, tariffs, and reuse/recycling.

This report describes the approach, including information sources and assumptions used, to estimate the costs and savings of SES Water demand-side options for use in water resources planning (WRMP19) and investment planning (PR19). This is part of a wider options identification and assessment process being undertaken for these plans.

AECOM asked Artesia to provide options information into an EBSD (Economics of Balancing Supply and Demand) workbook developed by decisionLab. In details, the aim of the project was to:

- To develop fully justified (cost/benefit) demand management strategies for the feasible option identified;
- To evaluate carbon cost for options taken forward;
- To feed options' information about cost and savings into an 'EBSD template workbook' developed by decisionLab and used to screen options as indicated by the EBSD requirements.

## 1.1 Structure of this report

This report contains the following sections:

- Section 2 summarises the feasible options and details those have costs and benefits identified, and justification for those not evaluated.
- Section 3 presents the costs and savings used in the analysis of water efficiency and metering options.
- Section 4 presents the costs and savings used in the analysis of water efficiency and metering options.
- Section 5 presents the bundle options created to achieve business plan targets.
- Section 6 summarises the assumptions used in assessing carbon costs.
- Section 7 summarises the AIC (average incremental cost) and saving results for central scenario for each option assessed.
- Section 8 details the data required by the EBSD workbook.

## 2 Feasible options list

Table 1 presents the complete list of feasible options and indicates which options have had costs and benefits assessed (CBA) in this stage of the project. Two additional options (113a and 399) have been added at a later stage following SES Water request of an AMR-based compulsory metering option. One final additional smart metering option (555) has been produced in order to achieve 80% meter penetration by 2024/25 and 90% by 2029/30.

Some of the options have not been assessed quantitatively – these are discussed further in section 2.1.

Table 1 Feasible option list

#	Option name	Score	CBA assessed?
Leakage			
073	Increasing ALC effort. Increase leakage find and fix budget by 'x' percent	17	Yes
302	Improved R&M efficiency	17	Yes
178	Raw water and WTW leakage reduction	19	No
301	Increasing ALC efficiency (detection and location)	20	Yes
303	Enhanced pressure management	21	Yes
399	Mains renewal <sup>1</sup>		Yes
900	Leakage Bundle <sup>1</sup>		Yes
Metering			
311	Smart metering of selected households	16	Yes
113	Smart metering of all households	20	Yes
113a	Compulsory metering (AMR) of all households <sup>1</sup>	20	Yes
312	Smart metering of selected non households	20	No
555	Smart metering – enhanced meter penetration <sup>1</sup>		Yes
600	Smart metering – enhanced meter penetration (higher meter penetration) <sup>1</sup>		Yes
Rainwater/greywater harvesting			
124	Installation of rainwater harvesting in new	21	No

<sup>1</sup> Options added at a later stage following SES Water request

	build non-households		
Tariffs			
038	Special tariff for sprinkler users	20	No
015	Increasing volumetric charges	21	No
800a	Tariffs – scenario A <sup>1,2</sup>		Yes
800b	Tariffs- scenario B <sup>1,2</sup>		Yes
Water Efficiency			
019	Household water efficiency programme (Company led, self-install)	18	Yes
020	Household water efficiency programme (Company led, plumber installed)	18	Yes
305	Domestic retrofit programme targeting high consumers	19	Yes
021	Household water efficiency programme (Partnering approach, home visit)	19	Yes
022	Non-household water efficiency programme (Company led, self-install)	19	Yes
308	Targeting leaking WCs, taps and showers	19	Yes
157	Dual flush toilet retrofits (company funded)	20	Yes
307	Variable infrastructure charge	20	Yes
700a	PR19 Option 1a <sup>1,2</sup>		Yes
700b	PR19 Option 1b <sup>1,2</sup>		Yes

## 2.1 Options not assessed quantitatively

### 2.1.1 Tariff options (038, 015)

Costs and benefits of tariff options remain uncertain – there have been several studies but the results have been mixed. Two of the most recent water-company led trials had slightly differing results. South West Water carried out a trial of a rising block tariff at 1,000 properties, on change of occupier, over the 2009-11 period. The company reported that this trial failed to produce significant behaviour change, and as a result it was unable to justify the major changes required to implement the scheme universally.

Wessex Water carried out a more extensive trial, for which interim results were reported in 2012. This trial, of 6,000 properties assessed the effectiveness of four different charging

<sup>2</sup> Options split into two phases to accommodate EBSD modelling

structures, including seasonal and rising block tariffs. The results were promising in terms of the observed reductions in water use. The simple seasonal and rising block charging structures have shown additional demand reductions compared to standard metered charges of 6% on average. However, customer acceptance of tariffs was low and this was seen as an important barrier to overcome before tariffs could be widely applied.

Wessex Water's study highlighted the benefits of smart metering, particularly in the context of tariffs, and this technology will enable a wide range of tariffs to be applied. However, this means that tariff options could only be implemented after smart metering has been delivered – something that is at least 10 years away.

Therefore the feasible tariff options have been assessed in broad terms only, based on these observations.

#### Increasing volumetric charges (015)

##### Description

This option would involve increasing the volumetric charge for water supply. Increasing the volumetric charge would encourage customers to use water more wisely, reducing demand.

##### Discussion

The technical requirements for this option are simple: an increased unit price of water could be applied with current metering technology, assuming that current approach to charging based on metered consumption is maintained. This could be a one-off increase, or an annual increase up to a pre-determined level

Approval from Ofwat would be a necessity as this option is likely to affect the tariff basket and could also influence future price determinations. Consultation with CCWater would be strongly recommended. It would be necessary to set out and communicate a price increase policy to customers.

It is known that the relationship between water use and price is relatively inelastic – i.e. a large increase in the volumetric charge for metered customers would be required to effect a reduction in demand. It may be necessary to reduce unmeasured household charges in order to maintain the tariff basket. This would be counterproductive as it would create a disincentive to opt for a metered bill for a large number of customers.

Therefore, whilst this is a technically simple option, the regulatory challenges and uncertainties are significant and the ultimate benefit, in terms of overall customer water efficiency, are also questionable. Consequently this option is not assessed further.

Special tariff for sprinkler users (038)
<p><b>Description</b></p> <p>This option would involve the introduction of time based volumetric charge that incentives off peak usage for sprinkler users.</p>
<p><b>Discussion</b></p> <p>The option would involve an optional special tariff with time-based volumetric charge that would incentivise off peak usage for sprinkler users. This means several different rates, depending on the time of day the sprinkler is used.</p> <p>The tariff would likely benefit high user, which could shift sprinkler use to other times of the day to save money.</p> <p>The main technical requirement of the option is that a smart meter would be necessary to be able to record peak/off-peak usage. Current meter technology and meter-read frequency do not offer the capability at the required resolution. Therefore, a smart meter installation programme would be necessary. Additional analysis would also be needed to assess the optimal peak/off-peak selection.</p> <p>Due to the technical requirements and the uncertainties around the smart meter programme implementation, this option is not assessed further.</p>

## 2.1.2 Installation of rainwater harvesting in new build non-households (124)

Storm water runoff from commercial buildings has potential for water capture and reuse<sup>3</sup>. Historically roof run off was rapidly removed from site, now this is recognised as a resource and technologies are emerging to resolve this use.

Nevertheless, this option is problematic because of the new retail market for non-households, which makes it difficult for wholesale water companies to provide advice to non-household customers. Also, it is difficult to estimate the savings that would result from this option, even assuming it is practicable. For example, it would be very difficult to estimate how many developers take up the offer and also what is the number and type of non-households which would be built.

<sup>3</sup> Lucke, T., Beecham, S., Zillante, G. (2007) Rainwater harvesting options for commercial buildings using siphonic roof drainage systems. International transitions conference, Australian Industry of Building Surveyors, Adelaide, 2007.

#### Installation of rainwater harvesting in new build non-households (104)

##### Description

This option would involve a reduced infrastructure charge for developers that install rainwater/greywater harvesting system in newly built non-households.

##### Discussion

The Infrastructure Charge is payable where new or existing premises are connected for the first time to the public water supply or to a public sewer, either directly or indirectly. The charge is set out by the water company with amounts that can vary based on the characteristics of the property.

The option would involve the company offering a reduced infrastructure charge for developers that agree to install rainwater/greywater harvesting system in newly built non-households. The company could offer different levels of discounts to developers based on the water-saving capabilities of the system put in place.

Storm water runoff from commercial buildings has potential for water capture and reuse<sup>3</sup>; however there is no sufficient evidence on how the systems work in different type of non-households properties. Additionally, there is not enough data on how many and what type of non-household developments are planned in the company area. It is also difficult to estimate the number of developers which would pick up the offer and what type of system they would build.

Due to the aforementioned uncertainties, this option is not assessed further.

### 2.1.3 Smart metering of selected non households (312)

The same rationale used for option 124 applies to the smart metering of selected non households. In this case the main issue is the consideration of uncertainties around retail separation in the non-household "market".

#### Smart metering of selected non households (312)

##### Description

This option would involve the installation of a smart meter for selected non-households.

##### Discussion

The option would involve identifying non-households with largest water consumption. A smart meter would be installed in the selected non-households. This would help the customers understand their water consumption and would incentivise them to reduce it. Customer would be also offered advice on how to diminish their water demand and improve efficiency.

The main technical problem around this option is that there is no sufficient information around retail separation and likely effect of smart meter on non-household. Therefore, this option is not assessed further.

### 2.1.4 Raw water and Water treatment work (WTW) leakage reduction (178)

This option would involve reducing leakage on raw water mains and through the wastewater treatment work (WTW) to reduce abstraction. The option would increase the deployable output rather than reduce demand; therefore, it is outside the scope of the demand side assessment.

Due to the aforementioned reasons, the option has not been assessed.

Smart metering of selected non households (312)
<p><b>Description</b></p> <p>This option would involve reducing leakage on raw mains and through the WTW to reduce abstraction.</p>
<p><b>Discussion</b></p> <p>Leakage at raw mains and through WTW reduce the water available to customers. The option would need to identify the best cost-effective approach between sensitivity and location accuracy, cost and ease of use on the other. It is likely that the option could potentially save a lot of water.</p> <p>However, not enough information are available on the asset and leakage levels at these locations. Additionally, the option would increase the deployable output rather than reduce demand.</p> <p>Therefore, this option is not assessed further.</p>

## 3 Costs and savings of feasible water efficiency and metering options

### 3.1 Water efficiency

Below are the considerations that were applied to the analysis of each of the water efficiency options:

- The number of households targeted per year is based on a percent of total households; this can be overwritten or varied.
- The length of the programme (in years) is how long the delivery of the option lasts for and can be changed by the modeller.
- Longevity of savings – defined as savings that persist for five years after installation, and based on the assumption that products such as tap inserts, low-flow showerheads and cistern displacement devices will remain installed for a relatively short time. An average value of five years has been used to represent this period of time, taking account of the likely period that these products are installed. More durable devices (such as ecoBeta dual flush retrofits) and fixes of leaking toilets will last for a longer period.
- Uptake rate represents the percentage of the properties contacted that choose to take part in the programme.
- Suitability is the percentage of those properties that are suitable and end up receiving part or all of the retrofit. (This may also be affected by other factors such as appointments being met, etc.).
- Unit costs are based on SES Water actual cost where possible.
- The marketing cost varies according to the number of properties involved in the option.

### 3.1.1 Modelling the water savings

For most of the options, it is assumed that the water savings delivered in each year will persist at that level for a period of 5 years and then revert to zero. Where an option delivers over several years (e.g. over 5 years) then the year 1 savings endure until year 5, year 2 savings until year 6, etc. This provides a rectangular profile for water efficiency delivery (in the text below this is referred to as the 'original' method).

An alternative approach that may have been used is to assume that the savings delivered in year 1 then decay using a half-life decay curve, with the half-life set to half of the asset life of the water efficiency fitting.

Artesia decided to use the rectangular profile for each year's water efficiency delivery, rather than the half-life profile. This choice was made because it makes the modelling of the water savings in each option simpler and more flexible in the EBSD workbook. The approach was agreed with SES Water.

A more detailed explanation is presented in the Appendix.

### 3.1.2 Water Efficiency costs and savings

Table 2 presents the main cost estimates and assumptions used for the central value estimate. Cost of devices have been agreed with SES Water based on their current costs. Upper and lower cost variations can be defined because in general these values are less well defined than for water saving estimates. At present, the default values for upper and lower costs estimates are set at  $\pm 20\%$  of the central value.

Table 3 presents the devices installed and/or fixes associated with each efficiency option and associated savings. Savings have been agreed with SES Water and are based on a combination of evidence, from assumptions currently used in the Water saving calculator offered by SES Water and from the WEF evidence base H2eco<sup>4</sup>. Lower estimate is 50% of central estimate; upper is 150% of central estimate.

---

<sup>4</sup> Ashton V, Lawson R, Marshallsay D and Ponsonby K (2015) Water efficiency evidence base statistical analysis - Report Number AR1096 - Client: Water efficiency collaborative fund via Dŵr Cymru. *Artesia Consulting Ltd*

Table 2 Cost of water efficiency options

Ref	Cost item	Unit cost	Units
157	Dual flush toilet plumber cost and travel - private	£50.00	per property
157	Dual flush ecoBeta toilet device	£12.85	per item
157	Dual flush communication, management and evaluation	£8.00	per property
157	Dual Flush marketing campaign	£5000.00	per 10000
019	Company led communication, management and evaluation	£8.00	per property
019	Company led materials	£8.61	per visit
019	Company led marketing campaign	£5000.00	per 10000
307	loss of revenue - lower scenario	£25.03	per property
307	loss of revenue - central scenario	£50.06	per property
307	loss of revenue - upper scenario	£67.05	per property
307	Internal company cost	£2500.00	per 5000
020	Company led Plumber per visit	£50.00	per visit
020	Company led materials	£22.43	per visit
020	Company led communication, management and evaluation	£8.00	per property
020	Company led marketing campaign	£5000.00	per 10000
308	Company led marketing campaign	£5000.00	per 10000
308	billing data analysis to ID high users - possible leakage	£2.00	per property
308	Company led Plumber per visit	£50.00	per visit
308	Company led materials	£12.85	per visit
308	Company led communication, management and evaluation	£8.00	per property
305	Company led Plumber per visit	£50.00	per visit
305	Company led materials	£22.43	per property
305	Company led communication, management and evaluation	£8.00	per property
305	Company led marketing campaign	£5000.00	per 10000
305	billing data analysis to ID high users	£2.00	per property
022	Non HH self-install products ( 3 x CDD, 3 x taps) & postage	£10.00	per property
022	Non HH self-install communication, management and evaluation	£8.00	per property
022	Non HH self-install Marketing campaign	£2500.00	per 5000
021	Company led Plumber per visit	£25.00	per visit

021	Company led materials	£22.43	per visit
021	Company led communication, management and evaluation	£8.00	per connection
021	Marketing	£5000.00	per 10000

Table 3 Water efficiency option savings

Option	Measure	Lower	Central	Upper	unit
019	CDD+showerhead+tap inserts+shower timer	17.7	35.3	53.0	l/prop/d
020	ecoBeta+tap inserts+showerhead+hosepipe trigger gun	32.4	64.9	97.3	l/prop/d
305	ecoBeta+tap inserts+showerhead+hosepipe trigger gun	32.4	64.9	97.3	l/prop/d
021	ecoBeta+tap inserts+showerhead+hosepipe trigger gun	32.4	64.9	97.3	l/prop/d
022	tap inserts (x3) + CDD (x3)	29.7	59.4	89.1	l/prop/d
157	Dual flush ecoBeta toilet device	20.5	41.0	61.5	l/prop/d
307	combination of different approaches (refer to option 307 section)	11.87	23.75	32.50	l/prop/d
308	fix leaking toilet	107.50	215.0	322.5	l/prop/d
200	Washing Machine	14.3	16.9	17.7	l/prop/d

When assessing cost benefits of water efficiency options, the marginal cost of water has been considered to determine the value of water saved because less pumping is required. The marginal costs represents, effectively, the change in costs as a result of a specified change in demand thus entailing a reduction in operational costs. The value of marginal cost of water for SES Water is £202/MI.

### 3.1.3 Household Water efficiency (WEFF) programmes (019,020, 021)

The household water efficiency (WEFF) programmes include option 019 (Household WEFF programme company led self-install), 020 Household WEFF programme company led plumber Install) and 021 (Household WEFF programme partnering approach home visit).

Option 019 involves the distribution of water efficiency information and devices as a kit. The kit includes: an aerated shower head, a save a flush cistern displacement device, aerated tap inserts, universal plug and a shower timer. The water efficiency devices would be installed by the customer and the devices chosen are easy to install.

Option 020 would involve a home visit by plumber to install water efficient devices. The visit will also provide information on behavioural change and impact on water use. The home visit would be delivered by the water company; most likely via an external contractor. Efficiency devices are installed by a qualified plumber and householders are encouraged to change water-use behaviour by provision of water efficiency information.

Option 021 would involve a home visit by plumber to install water efficient devices. The visit will also provide information on behavioural change and impact on water use. The home visit would be delivered via and external contractor, and using a partnering approach with organisations such as Housing Associations or Local Authorities. Therefore, lower costs are assumed. Efficiency devices are installed by a qualified plumber and householders encouraged to change water-use behaviour by provision of water efficiency information.

For all WEFF programmes, the number of households targeted per year is currently based on 10% of total households, but can be varied by the modeller. Savings are assumed to last for 5 years.

### 3.1.4 Domestic retrofit targeting high consumers (305)

Domestic retrofit programme which targets metered customers with high consumption as identified by billing information. Customers would be offered a range of devices to help to reduce consumption. This would be a visit and fix/install programme.

This option would involve a home visit by plumber to install water efficient devices. The visit will also provide information on behavioural change and impact on water use. The home visit would be delivered by the water company, most likely via an external contractor. Efficiency devices are installed by a qualified plumber and householders encouraged to change water-use behaviour by provision of water efficiency information. Uptake rates are assumed to be high as this will directly help the customer save water and therefore save money so in the customers' best interest to participate. Will require additional analytics to identify the high consumers from billing data.

The number of households targeted per year is currently based on 5% of total households, but can be varied by the modeller. Savings are assumed to last for 5 years.

### 3.1.5 Non Household WEFF company led self-install (022)

This self-install programme initially proposes the provision of cistern displacement advice or dual flush retrofit devices and tap inserts and provision of "saving your business" water use information.

There are a total of 13,574 non-household properties (excluding unknowns). We have selected a total of 1,534 for this option. This is for a variety of reasons, including; those with greatest consumption associated with them, and those considered to be 'big wins' in terms of the water saving on consumption component. These organisations include; schools, offices, healthcare and hotels. These four sectors will have high toilet, shower and tap use which can yield the greatest water saving. Based on Thames Water "Smarter Business Visits" they have seen significant water savings<sup>5</sup>. In some cases water savings have been 3,600l/d by using sensor urinals, sensor taps and propel air ultra-low flush toilets. Savings are assumed to last for 5 years.

---

<sup>5</sup> Tucker A (2017) Water Efficiency with our Smart Meter Rollout - WWT Conference (March 2017). Available at: <http://events.wwtonline.co.uk/smartnetworks/wp-content/uploads/sites/106/2017/03/Andrew-Tucker.pdf>

### 3.1.6 Campaign targeting domestic customers with high consumption - leaking toilets (308)

The domestic retrofit programme targets metered customers with high consumption. They are identified by billing information and this is regarded as an effort to tackle internal leakage - in particular leaking toilets. Customers would be offered a visit by a plumber to ascertain if the property has a leaking toilet and then fix it. The visit will also provide information on behavioural change and impact on water use. The assumed water saving is based on evidence from Thames metering programme<sup>5</sup>. The option targets metered customers and would require some analytic cost for the identification of high users.

Not enough information is available on toilet fix programmes at the current time, therefore a series of assumption on continuation of saving and uptake rate have been made. The programme target the top 5% of users. Uptake rate (high consumers that actually have a leak) are assumed at 5% of the targeted properties for central scenario (lower = 1%, upper 10%); this can be varied by the modeller if/when more detailed data are available. Savings are assumed to last for 15 years.

### 3.1.7 Dual flush toilets retrofit (157)

This option is a Water Company funded dual flush retrofit scheme. The programme will start with a company-wide marketing campaign to engage with consumers. Those who apply to take part in the scheme will receive a visit from a plumber to their property and a dual flush mechanism will be retrofitted to the toilet.

The number of households targeted per year is currently based on 20% percent of total households, but can be varied by the modeller. Savings are assumed to persist for 15 years.

### 3.1.8 Variable infrastructure charge (307)

The scenarios have been supplied by SES Water based on a hypothetical 1800 property development.

The Government updated Part G of the Building Regulations in 2010, setting a whole building standard of 125 litres per person per day for domestic properties. Based on the efficiency level company could offer the following discounts to Infrastructure Charges might then apply:

- 15% reduction if smart meters are fitted, allowing the customer to track their water usage at least daily. A saving of 5 litres per person per day is assumed, i.e. 120 litres/person/day.
- 30% reduction if all bathroom fittings are 'A'-rated based on the Water Label or either rainwater harvesting or greywater recycling is fitted. This equates to a water usage of around 105 litres/person/day.
- 50% reduction if all bathroom fittings are 'A'-rated based on the Water Label AND either rainwater harvesting or greywater recycling is fitted. This equates to a water usage of around 80 litres/person/day.

Three Scenarios have been developed based on different uptake percentages by the developers, as presented in Table 4.

Table 4 Variable infrastructure charge uptake scenarios

Water Efficiency options	Lower	Central	Upper
	Scenario 1	Scenario 2	Scenario 3
	(low WE)	(medium WE)	(high WE)
Standard	75%	50%	35%
Option 1 (smart meters)	10%	20%	25%
Option 2 (A rated or RWH/GWR)	10%	20%	25%
Option 3 (A rated and RWH/GWR)	5%	10%	15%
Reduction in income	£45,057	£90,115	£120,690
Water Savings (m3/year)	7,801	15,603	21,352

Assuming a standard charge per property of £357.6, the average cost (loss of revenue) and saving per property presented in Table 5 would be achieved.

Table 5 Variable infrastructure charge cost (loss of revenue) and saving

Cost and Savings	Lower	Central	Upper
	Scenario 1	Scenario 2	Scenario 3
	(low WE)	(medium WE)	(high WE)
Average cost (loss of revenue) per property - £	25.03	50.06	67.05
Average saving - l/prop/day	11.87	23.75	32.50

Savings are assumed to persist for fifteen years after installation due to the combination of devices installed.

### 3.2 Metering projects

Below are the assumptions used when assessing the metering options (311, 133, 113a, 555):

- Meter costs are based on company-specific variables where possible, including meter cost, survey and installation cost, cost of meter reads, and supply pipe repair costs.
- The number of properties is obtained from the household demand forecast for the SES water resource zone. The maximum meter penetration is assumed to be 90% of total properties at the end of the forecast period (2080). Whilst compulsory meter for unmeasured households is proposed to be achieved in 10 years.

- The saving values for compulsory metering are based on results of metering projects presented in the update to the water efficiency evidence base<sup>4</sup>. Dumb and AMR savings are based on the findings from Southern Water<sup>6</sup> and South East Water<sup>4</sup>. The additional effect of smart metering is based on results from the Anglian Water in-house display project (in the WEFF evidence base report)<sup>4</sup>.
- For compulsory metering using dumb/AMR meters, we have used evidence from Southern Water (Southampton University study)<sup>6</sup>. The study indicates overall saving, including 'anticipation' effect, of 16.5% for AMR and we have initially used this value as the 'mean water saving'. However, the additional saving obtained through AMR are based on more frequent readings and therefore more regular feedback to the customer. Because SES Water AMR meters are likely to be used as dumb, with no additional readings, the mean estimate is set a 14.5%. This has been agreed with SES Water. The lower estimate of water savings taken from the same study suggests a 13.5% overall reduction in demand and reduced to 11.6% for the same reason. The upper saving of 18.5% reduction in demand is taken from the results of South East Water's metering programme (taken from table 48 of WEFF evidence base report)<sup>4</sup> and reduced to 17.4%.
- For the additional effect of smart metering, 5.7 l/prop/d saving was used which is from the Anglian Water in-home display project This equates to a central value of 1.5% on average unmeasured household consumption. Lower and upper estimates are assumed at 1% and 2% respectively.
- Compulsory metering with smart meters is estimated to deliver 18% savings, based on the additional benefit of in-home displays (as per previous analysis). This is considered a conservative estimate, as further savings are likely from data that will be collected, e.g. on leakage, comparative consumption rates and trends in consumption over time. However, this has not been included at present as there are no data to support this.
- Selective compulsory metering has been based on the assumption that highest users would reduce their consumption by the same percentages used for the other compulsory metering projects. However, this is unlikely to be the case, since there is insufficient evidence to investigate the potential savings based on household type. It is assumed to target the top 5% water users

As for water efficiency options, the marginal cost of water has been considered to determine the value of water saved.

Table 6 presents meter option cost estimates, and Table 7 illustrates the potential savings.

---

<sup>6</sup> Ornaghi C and Tonin M (2015). The effect of metering on water consumption. 1–9.

Table 6 Metering option Costs

	311 - high	113 - AMI	113a - AMR
Meter Cost	£36	£38	£36
Meter Installation External	£123	£123	£123
Meter Installation Internal	£58	£58	£58
Meter replacement strategy	£39	£39	£39
Meter Survey	£29	£29	£29
SPL repairs	£300	£300	£300
Meter reads (single read)	£2.00	£0	£0.5
Networks Annual Charge	£1/property	£1/property	
Network Mast(s) installation	£150,000	£300,000	
Communications Interface	£137,895	£6,628,066	£10,625
Analytics Annual Charge		£100,000	£50,000

Table 7 Metering option Savings

Meter type	Lower	Central	Upper
DUMB	11.60%	14.50%	17.40%
AMR	11.60%	14.50%	17.40%
AMI	14.4%	18.0%	21.6%
M to Smart	1.00%	1.50%	2.00%

### 3.2.1 Smart metering – enhanced meter penetration (555) and enhanced meter penetration (600)

These options have been added in at a later stage to assess cost and savings for a metering scenario of 80% meter penetration by 2024/25 and 90% by 2029/30 (option 555) and 85% meter penetration by 2024/25 and 95% by 2029/30 (option 600). For these options, only meter install and maintenance costs for the additional meters will be included. The meter read and back office infrastructure costs just for additional meters are included in the costs. Meter replacement rate assumed to be 15 years. The estimated costs for the option are summarised in Table 8.

Savings are assessed for the additional smart meter installed only and are estimated at 18% (refer to the previous section for details).

Table 8 Metering Option 555 Costs

	555 - AMI
Meter Cost	£38
Meter Installation External	£123
Meter Installation Internal	£58
Meter replacement strategy	£39
Meter Survey	£29
SPL repairs	£300
Meter reads (single read)	£0
Networks Annual Charge	£1/property
Network Mast(s) installation	£150,000
Communications Interface	£676,265
Analytics Annual Charge	£35,000

## 4 Costs and savings of feasible leakage options

### 4.1 Leakage options

#### 4.1.1 Enhanced Pressure management (303)

The scope for new, additional or improved pressure management is assessed by inspection of control point (CP) pressures. CP pressures are compared with an agreed pressure threshold that will ensure that standards of service to customers would not be prejudiced; this is normally taken to be a surrogate pressure of 20 to 25 meters and provides a buffer to allow for uncertainty and friction losses between the CP point and customer stop taps.

The differences between the current CP pressures and the threshold will define the potential additional head drop that could be implemented and hence the potential reductions in average zone night pressures (AZNP). The current and potential AZNP values will be used within the Fixed and Variable Area Discharges "FAVAD" equation that relates pre and post AZNP values to leakage levels:

$$L_1 \times HDF_1 = L_0 \times HDF_0 / (AZNP_0 / AZNP_1)^{N1} \quad \text{Equation 1}$$

Where:

$L_0, L_1$  = net night flows before and after pressure management (m<sup>3</sup>/hr).

$HDF_0, HDF_1$  = hour day factors before and after pressure management

The exponent N1 is a function of the PMA asset condition. A value of 1.118 has been used (which is the average of a number of UK studies).

HDF<sub>1</sub> values will be dependent on the proposed scheme type. The rationale in Table 9 has been used to define scheme types:

Table 9 PMA scheme types

Existing scheme type	New scheme type
Gravity	Fixed outlet
Fixed outlet	Retro-fit flow modulation
Flow modulation / Time profile / Closed loop	Optimisation

HDF<sub>1</sub> values will use the average of a sample of current HDF values of the same scheme type.

The current PMA net night flow values, L<sub>0</sub> have been used within equation 1 to determine L<sub>1</sub>. The difference between L<sub>0</sub> and L<sub>1</sub>, define the scheme leakage savings.

#### 4.1.2 Increasing ALC effort. Increase leakage find and fix budget by 'x' percent (073)

This option assumes no change in the current ALC process other than a range of increases in manpower resource levels (beyond those required to deliver the short-run SELL) in order to achieve as far as possible the steps in leakage. At some point these may be constrained by policy minimum / background leakage levels. Transition and annual maintenance costs are estimated separately. The total costs and leakage savings profiles associated with each option have been quantified. Main costs are detailed in Table 10.

Table 10 Leakage – Increasing ALC effort costs

Job	Unit cost (£/job)	Unit cost (£/hour)
Monitoring		344,110
Leakage detection - fixed costs		26,732
Leakage detection - variable costs		425,860
Mains repair	3,123	
Communication Pipes	715	
Ferrule	1,938	
Meter	34	
Stop cock	900	
Supply pipes	730	
Fire hydrant	192	

#### 4.1.3 Improve efficiency options – Increasing ALC efficiency (detection and location) (301); Improved R&M efficiency (302)

Both these options assumes change in the current ALC process to increase efficiency in detection and location (option 301) and replacement and maintenance activities (option 302).

For option 301 scenarios are:

- Reduce detection and sweep time by 10%
- Reduce detection and sweep time by 15%
- Reduce detection and sweep time by 20%

For option 302 scenarios are:

- Reduce repair and maintenance time by 10%
- Reduce repair and maintenance time by 15%
- Reduce repair and maintenance time by 20%

Transition and annual maintenance costs are estimated separately. Costs are based on Table 10 and recalculated according to efficiency level and leakage savings.

#### 4.1.4 Mains renewal (399)

These options assumes different rates of mains renewals based on 4 scenarios supplied by SES Water.

The scenarios are detailed in the Table 11 and Table 12.

Table 11 Mains renewal scenarios

Option Code	Scenario Description
Baseline	Base Scenario - Leakage at 24.0 MI/d (stable serviceability)
399a	Scenario 1 - Flat Costs (leakage at 23.6 MI/d in AMP7)
399b	Scenario 2 - leakage at 22.8 MI/d (5% reduction)
399c	Scenario 3 - leakage at 21.6 MI/d (10% reduction)
399d	Scenario 4 - leakage at 20.4 MI/d (15% reduction)

Table 12 Mains renewal costs

Scenario	AMP7 Cost (£)	AMP 7 Length (km)	AMP8 Cost	AMP 8 Length (km)	AMP9 Cost	AMP 9 Length (km)
baseline	£28,866,564	112.64	£36,331,382	148.97	£41,222,172	176.16
399a	£36,636,138	140.23	£36,224,881	150.61	£35,096,169	153.40
399b	£43,136,051	174.63	£37,227,683	150.29	£41,384,094	181.83
399c	£62,875,101	256.19	£37,602,055	149.53	£41,703,858	182.54
399d	£86,598,431	357.82	£38,913,917	158.27	£43,897,962	182.75


Annual maintenance costs and savings are estimated based on the above assumptions. It is assumed that maximum savings are achieved at the end of AMP7 (5 year lead-in) and retained for the rest of planning period. Maintenance and replacement costs are kept flat after AMP9.

## 5 Bundled options

SES Water has set a target average per capita consumption (PCC) of 135 and 118 l/head/day respectively by 2024-25 and 2049-50. These values refer to a 1 in 10 Dry Year (DY) scenario. This is shown in the graph below as the grey line.

WRMP19 draft final plan included an enhanced smart metering option (MET555), which was set to start in 2020-21 and achieve 90% meter penetration by 2029-30. Other feasible options were not selected till 2059-60.

In the draft final plan, the combination of strategies produced a PCC profiles where targets were not met. This is shown in the figure below. Please note that the average PCC figures have been calibrated to 1 in 10 DY Scenario using the household consumption model.



**Figure 1 PCC target against draft final plan**

To meet the target, SES Water has proposed two strategies:

- A suite of water efficiency strategies: PR19 option 1. This is detailed in Table 13.
- A super-enhanced metering strategy set to achieve 95% meter penetration by 2029-30. This option would include compulsory metering.

Table 13 SES Water - Option PR19 1 cost and saving

Programme	Participants	Cost (£) per participant	Total Cost (£)	Savings (litres/day)	Savings (MLD)
Water Saving Packs	5000	£11.20	£56,000	25.00	0.125
HWEC (std visits)	10000	£42.00	£420,000	45.00	0.450
HWEC (products)	10000	£12.00	£120,000		
Housing Association (visits)	3000	£38.40	£115,200	45.00	0.135
Housing Association (products)	3000	£10.00	£30,000		
Generic campaigns	15000	£0.40	£6,000	2.00	0.030
Targeted engagement	10000	£4.80	£48,000	10.00	0.100
Total			£795,200	127.00	0.840

## 5.1 PR19 option 1 (700a & 700b)

Initially, Artesia have modelled the option with the proposed savings. The resulting profile was not sufficient to achieve the PCC targets. Therefore, Artesia have proposed an alternative Option PR19 1a and 1b, with the additional intervention of fixing leaky loos during household visits. Artesia have assumed:

- 5% of properties would have a leaky toilet;
- Fixing leaking toilet can achieve a saving of 215 l/prop/day where a leak is found; therefore, an average of 10.75 additional savings per property;
- Material cost for the fix would be £12.85; therefore, an average of £0.64 additional cost per property.

Additionally, we have assumed that:

- Uptake is 100%. This means that all properties targeted each year are affected by the strategies;
- Savings last for 5 years. This is consistent with the approach agreed with SES Water and used for all other WEF options;
- Option PR19 1 is run each year for 5 years. After this period, the savings for the properties targeted in the first year have disappeared and the program can be run again, in order to maintain the savings (this will need to be reflected in the cost); Scenarios 1a and 1b are modelled with different increasing commitment in the first years of implementation.

- The number of properties targeted is not fixed per year. The option is run together with one of the metering strategies and the option is applied to the number of properties required to achieve the PCC target. In the later years of the planning period more properties are targeted until all the properties in the company are include in the option. This is necessary to achieve the target saving required by 2050.

The modelling strategies result in two scenarios. Scenario 1a uses the metering of 80% by 2024-25 and 90% by 2029-30. Scenario 1b uses the metering of 95% by 2029-30. The PCC profiles achieved through these are shown in the figure below (1a in blue and 1b in red). These measures achieve the target PCC is until 2039-40 for option 1a and till 2044-45 for option 1b. However, neither scenario achieves the target PCC of 118 by 2049-50.




Figure 2 PCC target against proposed strategies

## 5.2 Tariffs (800a & 800b)

Tariff options, including option 017, Seasonal Tariffs; and option 018, Rising Block Tariffs were either screened out of the feasible options list, or not assessed quantitatively, due mainly to lack of data (see section 2.1).

From 2040 onwards, the existing water efficiency options reach their maximum capacity and therefore a further option was created based on using tariffs to change water use behaviour. Two versions of the tariff option were created to deliver an increasing water saving over time. The water savings in terms of per capita consumption are show in the following table.

Table 14 Water saving for each tariff option in PCC (l/head/day)


	Water saving per capita per day based on total population (l/head/day)									
	2040-41	2041-42	2042-43	2043-44	2044-45	2045-46	2046-47	2047-48	2048-49	2049-50
<b>TAR 800a</b>	0.24	0.69	1.24	1.89	2.53	3.41	4.15	4.82	5.49	6.15
<b>TAR 800b</b>	0.00	0.00	0.00	0.00	0.00	1.13	1.88	2.56	3.24	3.92

The evidence base in the UK for the impact of tariffs is weak. Two of the most recent water-company led trials had slightly differing results. South West Water carried out a trial of a rising block tariff at 1,000 properties, on change of occupier, over the 2009-11 period. The company reported that this trial failed to produce significant behaviour change, and as a result it was unable to justify the major changes required to implement the scheme universally. Wessex Water carried out a more extensive trial, for which interim results were reported in 2012. This trial, of 6,000 properties assessed the effectiveness of four different charging structures, including seasonal and rising block tariffs. Wessex Water's trial suggests a saving in the region of 6% for simple seasonal or rising block tariffs. Customer acceptance in this trial was low, and this was seen as an important barrier to overcome before tariffs could be widely applied.

More research and developments are needed in the areas of customer communications and behaviour change before tariffs can be implemented. However, tariffs could form an important tool and lever for behaviour change in the future. Therefore, an innovative tariff option has been included in the future plans, but not until the fifth AMP in the current planning period.

Delaying this option until this period allows further research to be carried out into tariffs. It also allows time for the existing largely 'dumb' meter stock (and the associated meter data system) to migrate to a more intelligent system over the next 20 years, which in the future we envisage will be more suited to the implementation of innovative tariffs. It also allows time for the more certain water saving options, such as household audits, to be implemented and the savings from those to be quantified more accurately before implementing tariffs. The details of which specific types of tariffs will be implemented has not been defined, as it will build on the next 20 years of water efficiency and metering installation programmes, and allow the research that will be carried out over that time to lead the decision on which tariffs to use.

The PCC profiles resulting from these strategies are shown in the following chart (dotted blue line for 1a and dotted red line for 1b, both of which achieve PCC of 118 by 2049-50. Please note that profiles overlap the target PCC line).



**Figure 3 PCC target against proposed strategies and introduction of tariffs**

### 5.3 Bundle scenarios

The two bundles are shown in the tables below.

Table 15 Bundle 1

Option ref:	Option description	Additional explanation	Mandated option start date
MET 555	Metering option (90% metering penetration by		2020-21

	2030)		
WEFF 700a ph1	Water efficiency saving PR19 Option 1b (ph1)	Options are split because the EBSD sheet only allows up to 25 years for each option. Phase 1 starts in 2020-21, and the Phase 2 starts in 2045-46.	2020-21
WEFF 700a ph2	Water efficiency saving PR19 Option 1b (ph2)		2045-46
TAR 800a	New tariffs option - scenario a	Tariff strategies that are implemented to meet the target	2040-41

Table 16 Bundle 2

Option ref:	Option description	Additional explanation	Mandated option start date
MET 600	New metering option (95% meter penetration by 2030)		20-21
WEFF 700b ph1	Water efficiency saving PR19 Option 1b (ph1)	Because the EBSD sheet only allows up to 25 years for each option, we have had to split option 700 into two. Phase 1 starts in 2020-21, and the Phase 2 starts in 2045-46.	20-21
WEFF 700b ph2	Water efficiency saving PR19 Option 1b (ph2)		45-46
TAR 800b	New tariffs option - scenario b	Tariff strategies that are implemented to meet the target	45-46

## 5.4 Leakage bundle

Having reviewed the leakage option results from the draft plan, a single leakage bundle was created for the final plan to ensure consistency with the AMP 7 business plan. The bundle is based on the three leakage options of:

- Increased active leakage control (option 073),
- Use of pressure managed areas (option 303),
- Mains replacement (option 399).

Table 17 shows the percentage reduction in leakage within each of the asset management periods in the planning period.

Table 17 Leakage bundle

	Percentage reduction in leakage within each AMP		
	Active leakage control	Mains renewal	Pressure managed areas
AMP7	5%	5%	5%
AMP8	10%	5%	0%
AMP9	10%	5%	0%
AMP10	10%	5%	0%
AMP11	10%	5%	0%

## 6 Carbon Cost

Carbon cost for water efficiency and metering cost has been calculated based on the assumptions presented in Table 18 and Table 19.

Table 18 Carbon weights and costs

Assumptions	Unit cost	Source
0.356	Carbon emitted by production of 1MI of cold water (gCO <sub>2</sub> /l)	Veolia PR09
8.1	Carbon emitted by production of 1MI of hot water (tCO <sub>2</sub> /l)	Ofwat 2011
30%	% of water consumed that is heated	Ofwat 2011
£29	Cost of traded carbon	DECC 2011
£64	Cost of non-traded carbon	DECC 2011

Table 19 Carbon assumptions travel and materials

Item	Value	Units
Travel	0.00019469	tCO <sub>2</sub> e/MI/km
Composite* meter or water saving device	0.00160875	tCO <sub>2</sub> e/property

\* Composite meter 95% plastic 5% metal 500g

Carbon costs are calculated following a yearly profile and then summarised in the EBSD workbook as:

- CAPEX carbon costs - carbon cost for capital expenditure up to the 12<sup>th</sup> year. This include device installed plus mileage needed for the installation
- OPEX carbon costs - Yearly operational carbon costs that the option requires for each year the project is run. This includes benefits due to less water pumped plus cost associated with operational activities if present.

## 7 Summary of results

The following table presents the central estimate AIC values, the average annual and discounted average annual savings for all original feasible options assessed. The figures are calculated considering the 25-years period required by the EBSD model.

Table 20 Summary of AIC and savings for feasible options (over 25 years planning period)

Option Full Code	Option Description	AIC p/m3	Average saving (MI/d)	Discounted Average saving (MI/d)
Water efficiency				
WEFF 019	WEFF 019 - Household WEFF programme company led self-install	83.72	0.02	0.02
WEFF 020	WEFF 020 - Household WEFF programme company led plumber install	59.98	0.13	0.11
WEFF 305	WEFF 305 - Domestic retrofit targeting high consumers	57.99	0.10	0.08
WEFF 021	WEFF 021 - Household WEFF programme partnering approach home visit	36.97	0.13	0.11
WEFF 022	WEFF 022 - Non HH WEFF company led self-install	4.95	0.003	0.002
WEFF 308	WEFF 308 - Campaign targeting domestic customers with high consumption - leaking toilets	-10.78	0.26	0.17
WEFF 157	WEFF 157 - Dual flush toilets retrofit	25.99	0.51	0.33
WEFF 307	WEFF 307 - Variable infrastructure charge	31.79	0.17	0.11
Metering				
MET 311	MET 311 - Smart metering of selected households	44.30	0.42	0.24
MET 113	MET 113 - Compulsory Smart Metering of all households	173.12	5.53	2.95
MET 113a	MET 113a - Compulsory Metering of all households	55.44	3.77	2.02
MET 555	MET 555 – Smart metering – enhanced meter penetration	39.76	2.31	1.28
Leakage				
LEAK 073_a	LEAK 073_a - Increased ALC effort_a	37.72	1.30	0.64
LEAK 073_b	LEAK 073_b - Increased ALC effort_b	38.67	2.48	1.23

LEAK 073_c	LEAK 073_c - Increased ALC effort_c	28.39	1.64	0.88
LEAK 073_d	LEAK 073_d - Increased ALC effort_d	35.67	1.24	0.59
LEAK 073_e	LEAK 073_e - Increased ALC effort_e	48.27	0.84	0.36
LEAK 073_f	LEAK 073_f - Increased ALC effort_f	26.17	1.84	1.04
LEAK 073_g	LEAK 073_g - Increased ALC effort_g	26.80	1.44	0.72
LEAK 073_h	LEAK 073_h - Increased ALC effort_h	41.90	1.04	0.46
LEAK 073_i	LEAK 073_i - Increased ALC effort_i	33.73	3.28	1.76
LEAK 073_j	LEAK 073_j - Increased ALC effort_j	41.74	2.48	1.18
LEAK 073_k	LEAK 073_k - Increased ALC effort_k	55.42	1.68	0.71
LEAK 301_a	LEAK 301_a - Improve ALC efficiency_a	23.90	1.22	0.68
LEAK 301_b	LEAK 301_b - Improve ALC efficiency_b	25.39	1.83	1.02
LEAK 301_c	LEAK 301_c - Improve ALC efficiency_c	27.02	2.44	1.36
LEAK 302_a	LEAK 302_a - Improve RM efficiency_a	20.22	0.13	0.08
LEAK 302_b	LEAK 302_b - Improve RM efficiency_b	20.38	0.21	0.12
LEAK 302_c	LEAK 302_c - Improve RM efficiency_c	20.53	0.28	0.16
LEAK_303	LEAK 303 - Enhanced pressure management	-10.67	1.20	0.71
LEAK_399_a	LEAK_399_a - Mains renewal_a	-111.18	0.37	0.21
LEAK_399_b	LEAK_399_b - Mains renewal_b	214.95	1.10	0.62
LEAK_399_c	LEAK_399_c - Mains renewal_c	255.83	2.21	1.25
LEAK_399_d	LEAK_399_d - Mains renewal_d	308.99	3.31	1.87

## 8 EBSD Workbook output

Information and results about each options have been outputted into an EBSD workbook developed by decisionLab. The file is supplied together with this report.

Artesia were required to provide info about:

- General option information (such as name, description and code).
- Carbon costs.
- FOPEX profile up to 25<sup>th</sup> year – total cost expenditure for each option up to year 25.
- Yield in MI/d up to the 25<sup>th</sup> year - water saving in MI/d achieved by each option up to year 25.

## Appendix

### Feasible options: water efficiency - modelling the water savings

#### Introduction

In the WRMP19 feasible options sheets for the water efficiency options, we have assumed that the water savings delivered in each year persist at that level for a period of 5 years and then go to zero. Where an option delivers over several years (e.g. 5 years) then the year 1 savings last until year 5, the year 2 savings until year 6, etc.

An alternative approach, which we have used previously, is to assume that the savings delivered in year 1 then decay using a half-life decay curve, with the half-life set to half of the asset life of the water efficiency fitting.

For WRMP19 we decided to use the rectangular profile for each years' water efficiency delivery, rather than the half-life profile (in the text below this is referred to as the 'original' method). This choice was made because it makes the modelling of the water savings in each option simpler and more flexible in the feasible options sheet.

The purpose of this technical note is to quantify the impact of this choice, and to justify that the choice is robust.


#### Data and method

Data was used from Option WEFF 020; Household WEFF programme, company led plumber install.

This option carries out plumber installation of water efficiency devices each year for 5 years. Each year the programme delivers 22.63 Ml per year, persisting for another 4 years. For the half-life calculation we have assumed that the average asset life of the water efficiency devices is 7 years (a value that we have applied for similar options in WRMP14).

#### Results

The original (5 year savings in blue) and the half-life water savings (in red) per year for the option are shown in the figure below:



The 'original' profile delivers more water earlier, than the half-life profile; but then stops delivering water earlier than the half-life profile (which continues to deliver an ever-decreasing amount of water).

In the feasible options analysis, both the costs and the yield need to be discounted using net present value<sup>7</sup>. Therefore, in summarising the water savings delivered by both the original and half-life methods, we have discounted the volumes using a discount rate of 4.5%. The total savings and the discounted savings over the 25 year planning period are summarised in the table below.

	Central – Original 5 year saving	Central – Half-life decay saving	% difference
Total volume (MI)	566	623	10.1%
Total discounted volume (MI)	456	460	1.0%

### Conclusion

The reason for the use of the 5-year water saving profile was essentially made on pragmatic grounds, as it makes the water saving modelling simpler and more flexible to implement in the feasible options worksheets. The total volume savings for this method are about 10% lower than the half-life method. However, when using the discounted volume savings there is only about 1% difference in the two methods. As discounted savings should be used in the feasible options analysis, then we believe the use of the 5-year water saving profile is justified.

<sup>7</sup> "The underlying premise is that the unit of water has an economic value. It is this value that is discounted. However, because estimating the actual value of water is a difficult activity it is not usually undertaken and the value is left as a volumetric form". UKWIR: A framework for valuing the options for managing water demand, Ref: 07/WR/25/3

## Appendix C EBSD model output

## Report on EBSD model runs

Run	Undiscounted Cost	First year of option utilisation	Options disallowed	Costs/Yields	Drought
013 – Least Cost	-£173,671	2021	None	Most Likely	WDHR
014 – Least Cost	-£2,147,576	2021	None	Most Likely	1:200
015 - Environmental	£3,052,556	2021	R8, R22, R28	Most Likely	WDHR
016 - Environmental	£2,260,189	2021	R8, R22, R28	Most Likely	1:200
017 – Increased Level of Service	£12,800,767	2021	None	Most Likely	WDHR
018 – Increased Level of Service	£9,632,994	2021	None	Most Likely	1:200
019 – Stakeholder Choices	£171,299,498	2021 - mandatory	R5, R8, N4, R6, R21, R22, R26, R2, R10	Most Likely	WDHR
020 – Stakeholder Choices	£171,299,498	2021 - mandatory	R5, R8, N4, R6, R21, R22, R26, R2, R10	Most Likely	1:200
021 – Stakeholder Choices with 311 instead of 113	£33,760,658	2021 - mandatory	R5, R8, N4, R6, R21, R22, R26, R2, R10	Most Likely	WDHR
022 – Stakeholder Choices with 311 instead of 113	£32,980,382	2021 - mandatory	R5, R8, N4, R6, R21, R22, R26, R2, R10	Most Likely	1:200
023 – Stakeholder	£246,941,589	2021 - mandatory	R5, R8, N4, R6,	Most Likely	WDHR

Choices with Mains Replacement			R21, R22, R26, R2, R10		
024 – Choices with Mains Replacement	£62,568,618	2021 - mandatory	R5, R8, N4, R6, R21, R22, R26, R2, R10	Most Likely	1:200
025 – Relaxed Stakeholder Choices	£63,128,226	2021 - mandatory	R8, R21, R22, R26, R2, R10	Most Likely	WDHR
026 – Relaxed Stakeholder Choices	£57,963,117	2021 - mandatory	R8, R21, R22, R26, R2, R10	Most Likely	1:200
027 - Least Cost (stakeholder)	£2,297,770	2021	R10, R12, R12R, R13, R13R, R15, N8	Most Likely	WDHR
028 - Least Cost (stakeholder)	-£809,972	2021	R10, R12, R12R, R13, R13R, R15, N8	Most Likely	1:200
029 – Environmental Run (stakeholder)	£8,005,108	2021	R10, R12, R12R, R13, R13R, R15, N8, R8, R22, R28	Most Likely	WDHR
030 - Environmental Run (stakeholder)	£3,729,950	2021	R10, R12, R12R, R13, R13R, R15, N8, R8, R22, R28	Most Likely	1:200
031 – Increased Level of Service (stakeholder)	£25,854,855	2021	R10, R12, R12R, R13, R13R, R15, N8	Most Likely	WDHR
032 – Increased Level of Service	£22,100,673	2021	R10, R12, R12R, R13, R13R,	Most Likely	1:200

(stakeholder)			R15, N8		
---------------	--	--	---------	--	--

Costs for runs 13, 14 and to an extent 15 and 16 have very low costs. This is due to reductions in demand profiles from previous runs, and the selection of demand management options which have negative fixed operating costs in their lifespan. This is highlighted by the selection of option Leakage 303 – Pressure Management, which has large negative costs from year 2 of its lifespan, and is selected in 2021 in all runs. As the demand profile rises, (runs 17 and 18), or more expensive options are forced (runs 19 and 20), costs can be seen to rise, as they do with runs 21 and 22 (by a smaller amount due to using the smart metering of selected households option).

#### Mutual Exclusivities:

One increased ALC Effort option:

SESW-LEA-078a to SESW-LEA-078k

One increased ALC Efficiency Option:

SESW-LEA-301a to SESW-LEA-301c

One increased Repair efficiency option:

SESW-LEA-302a to SESW-LEA-302c

One Metering option from:

SESW-MET-311: Smart metering of selected households

SESW-MET-113: Smart Metering of all households

SESW-MET-113a: AMR Metering

One Water Efficiency option from:

SESW-WEF-019: Household WEFF programme company led self Install

SESW-WEF-020: Household WEFF programme company led plumber install

SESW-WEF-021: Household WEFF programme partnering approach home visit

SESW-WEF-157: Dual flush toilets retrofit

One Main Renewal option from:

SESW-LEA-399a: Mains renewal\_a

SESW-LEA-399b: Mains renewal\_b

SESW-LEA-399c: Mains renewal\_c

SESW-LEA-399d: Mains renewal\_d

### Phased Deliveries:

1. SESW-ASR-R21: North Downs Confined Chalk AR extension 2 (new borehole on SE side of Football Club) is dependent on: SESW-ASR-R2: North Downs Confined Chalk AR extension 1 (Bishopsford Road)
  2. SESW-RTR-R12R: 20MI/d transfer from Langley Park/North Looe Reservoirs to Outwood PS-reverse is dependent on: SESW-RTR-R12: 20MI/d transfer from Langley Park/North Looe Reservoirs to Outwood PS
  3. SESW-RTR-R13R: 12MI/d transfer from Langley Park/North Looe Reservoirs to Buckland-reserve is dependent on: SESW-RTR-R13: 12MI/d transfer from Langley Park/North Looe Reservoirs to Buckland
- 

### Comments:

The DO values in runs 13, 15, 17 and 19 are in line with the drought effect from Worst Drought on Historic Record. 14, 16, 18 and 20 are in line with the 1:200 drought scenario

The DO is reduced by 2.5MI/d for an existing transfer out to SEW in DYAA, and 5MI/d in DYCP

The mutually exclusive interdependencies are applied the same to all runs; the mandatory options are applied to runs 19 and 20. These are:

SESW-MET-113: Smart Metering of all households

SESW-LEA-078i: Increased ALC effort\_i

SESW-LEA-301c: Improve ALC efficiency\_c

SESW-LEA-302c: Improve RM efficiency\_c

SESW-LEA-303: Enhanced pressure management

- In runs 21 and 22 the mandatory options above are selected, with SESW-MET-113 being replaced with SESW-MET-311: Smart Metering of selected households

Transfers R12 and R13 have zero yield as they don't contribute to the S/D balance; they are growth options.

In runs 23 - 26 the mandatory options are the following:

SESW-MET-311: Smart metering of selected households

SESW-LEA-399d: Mains renewal\_d

Runs 27-32 had the mandatory options deselected.

## Report on EBSD model runs

Run	Undiscounted Cost	First year of option utilisation	Options disallowed	Costs/Yields	Drought
041 – Met555 plus 2035 export without R22/R28 – can start from 2020	£93,098,966	2020 - mandatory	R10, R12, R12R, R13, R13R, R15, R8, R21, R26, R2, R1, R22, R28	Most Likely	WDHR
43 – Final Run with N8 1in200	£93,292,651	2020 - mandatory	R10, R12, R12R, R13, R13R, R15, R8, R21, R26, R2, R1, R22, R28	Most Likely	1:200

### Mandatory Options

Runs have the following mandatory options selected:

- SESW-MET-555: Compulsory smart metering - higher meter penetration
- SESW-LEA-399d: Mains renewal\_d

### Mutual Exclusivities:

One increased ALC Effort option:

SESW-LEA-078a to SESW-LEA-078k

One increased ALC Efficiency Option:

SESW-LEA-301a to SESW-LEA-301c

One increased Repair efficiency option:

SESW-LEA-302a to SESW-LEA-302c

One Metering option from:

SESW-MET-311: Smart metering of selected households

SESW-MET-113: Smart Metering of all households

SESW-MET-113a: AMR Metering

One Water Efficiency option from:

SESW-WEF-019: Household WEFF programme company led self Install

SESW-WEF-020: Household WEFF programme company led plumber install

SESW-WEF-021: Household WEFF programme partnering approach home visit

SESW-WEF-157: Dual flush toilets retrofit

One Main Renewal option from:

SESW-LEA-399a: Mains renewal\_a

SESW-LEA-399b: Mains renewal\_b

SESW-LEA-399c: Mains renewal\_c

SESW-LEA-399d: Mains renewal\_d

#### Phased Deliveries:

1. SESW-ASR-R21: North Downs Confined Chalk AR extension 2 (new borehole on SE side of Football Club) is dependent on: SESW-ASR-R2: North Downs Confined Chalk AR extension 1 (Bishopsford Road)
2. SESW-RTR-R12R: 20MI/d transfer from Langley Park/North Looe Reservoirs to Outwood PS-reverse is dependent on: SESW-RTR-R12: 20MI/d transfer from Langley Park/North Looe Reservoirs to Outwood PS
3. SESW-RTR-R13R: 12MI/d transfer from Langley Park/North Looe Reservoirs to Buckland-reserve is dependent on: SESW-RTR-R13: 12MI/d transfer from Langley Park/North Looe Reservoirs to Buckland

## Report on EBSD model runs

Run	Undiscounted Cost (£)	First year of option utilisation	Options disallowed	Costs/Yields	Drought
Business Plan Run 5, weighted towards MET (WDHR)	£169,512,786	2020 - mandatory	R10, R12, R12R, R13, R13R, R15, R8, R21, R26, R2, R1, R22, R28 & all non-mandatory DM options	Most likely	WDHR
Business Plan Run 6, weighted towards MET (1in200)	£169,512,786	2020 - mandatory	R10, R12, R12R, R13, R13R, R15, R8, R21, R26, R2, R1, R22, R28 & all non-mandatory DM options	Most likely	1in200

### Mandatory Options

Runs F05 and F06:

Mandatory options in:

SESW-MET-600: Compulsory metering AMI - enhanced higher meter penetration
SESW-WEF-700b-ph1: PR19 Option 1b (phase 1)
SESW-WEF-700b-ph2: PR19 Option 1b(phase 1)
SESW-TAR-800b: Tariffs (scenario b)
SESW-LEA-900: Leakage bundle 1

Other option interactions are as follows, although options listed may be excluded from the runs:

#### Mutual Exclusivities:

One increased ALC Effort option:

SESW-LEA-078a to SESW-LEA-078k

One increased ALC Efficiency Option:

SESW-LEA-301a to SESW-LEA-301c

One increased Repair efficiency option:

SESW-LEA-302a to SESW-LEA-302c

One Metering option from:

SESW-MET-311: Smart metering of selected households

SESW-MET-113: Smart Metering of all households

SESW-MET-113a: AMR Metering

One Water Efficiency option from:

SESW-WEF-019: Household WEFF programme company led self Install

SESW-WEF-020: Household WEFF programme company led plumber install

SESW-WEF-021: Household WEFF programme partnering approach home visit

SESW-WEF-157: Dual flush toilets retrofit

One Main Renewal option from:

SESW-LEA-399a: Mains renewal\_a

SESW-LEA-399b: Mains renewal\_b

SESW-LEA-399c: Mains renewal\_c

SESW-LEA-399d: Mains renewal\_d

Phased Deliveries:

1. SESW-ASR-R21: North Downs Confined Chalk AR extension 2 (new borehole on SE side of Football Club) is dependent on: SESW-ASR-R2: North Downs Confined Chalk AR extension 1 (Bishopsford Road)
2. SESW-RTR-R12R: 20MI/d transfer from Langley Park/North Looe Reservoirs to Outwood PS-reverse is dependent on: SESW-RTR-R12: 20MI/d transfer from Langley Park/North Looe Reservoirs to Outwood PS
3. SESW-RTR-R13R: 12MI/d transfer from Langley Park/North Looe Reservoirs to Buckland-reserve is dependent on: SESW-RTR-R13: 12MI/d transfer from Langley Park/North Looe Reservoirs to Buckland



# SESWater EBSD Model Run Output



Case Name: Relaxed Stakeholder Choices (WDHR)

Code: Run025

Input file used: EBSD Input Template EBSD Input Template SESW PR19 v4.8 WDHR.xlsx


Date/Time of optimisation run: 10:30 24<sup>nd</sup> Nov 2017

## Options Used and Start Year:

iAOZ	Delivery Year	Is Option Utilised?
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-LEA-399d: Mains renewal_d	2021	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2021	<input checked="" type="checkbox"/>
SESW-MET-311: Smart metering of selected households	2021	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2055	<input checked="" type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2057	<input checked="" type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2064	<input checked="" type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESW-LEA-302c: Improve RM efficiency_c	2070	<input checked="" type="checkbox"/>
SESW-WEF-307: Variable infrastructure charge	2070	<input checked="" type="checkbox"/>
SESW-NGW-R28: Lowering pumps at Kenley and Purley	2072	<input type="checkbox"/>
SESW-WEF-022: Non HH WEFF company led self install	2075	<input checked="" type="checkbox"/>
SESW-WEF-021: Household WEFF programme partnering approach home visit	2075	<input checked="" type="checkbox"/>
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS    
 Bars   
 Lines   
 Capacity   
 Utilisation




Company Level  Single WRZ

PS

Bars  Lines

Capacity  Utilisation



Costs:

Display Mode:  Undiscounted  NPV

Assessment period: 2099

Undiscounted Cost of Solution  £k  £Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	11,412.266			11,412.266	11,412.266
Fixed Opex	1,493.420		46,732.788	48,226.208	48,226.208
Var Opex	3,463.547			3,463.547	3,463.547
Co2 Capex	1.054		0.004	1.058	1.058
Co2 Opex			-0.001	-0.001	-0.001
E&S Capex	0.292			0.292	0.292
E&S Opex	24.856			24.856	24.856
<b>SubTotal</b>	<b>16,395.435</b>	<b>0.000</b>	<b>46,732.791</b>	<b>63,128.226</b>	<b>63,128.226</b>
% of investment cost	25.972	0.000	74.028	100.000	

Existing WAFU Sources: Existing WAFU Bulk Imports: 0.000

Existing Transfers: Deficit Options

Are there any deficit options selected or used? **NO**



# SESWater EBSD Model Run Output



Case Name: Relaxed Stakeholder Choices (1 in 200)

Code: Run026

Input file used: EBSD Input Template EBSD Input Template SESW PR19 v4.8 1 in 200.xlsx


Date/Time of optimisation run: 16:40 24<sup>nd</sup> Nov 2017

## Options Used and Start Year:

iAOZ	Delivery Year	Is Option Utilised?
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-LEA-399d: Mains renewal_d	2021	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2021	<input checked="" type="checkbox"/>
SESW-MET-311: Smart metering of selected households	2021	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2054	<input checked="" type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2057	<input type="checkbox"/>
SESW-LEA-302b: Improve RM efficiency_b	2063	<input checked="" type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2065	<input type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESW-WEF-307: Variable infrastructure charge	2071	<input checked="" type="checkbox"/>
SESW-LEA-301a: Improve ALC efficiency_a	2073	<input checked="" type="checkbox"/>
SESW-WEF-022: Non HH WEF company led self install	2075	<input checked="" type="checkbox"/>
SESW-WEF-021: Household WEF programme partnering approach home visit	2075	<input checked="" type="checkbox"/>
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS DYAA   
  Bars   
  Lines   
  Capacity   
  Utilisation




Company Level  Single WRZ

PS

Bars  Lines

Capacity  Utilisation



Costs:

Display Mode:  Undiscounted  NPV

Assessment period: 2099

Undiscounted Cost of Solution  £k  £Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	8,894.609			8,894.609	8,894.609
Fixed Opex	318.200		48,723.535	49,041.735	49,041.735
Var Opex	0.994			0.994	0.994
Co2 Capex	0.961		0.004	0.965	0.965
Co2 Opex			-0.001	-0.001	-0.001
E&S Capex	0.014			0.014	0.014
E&S Opex	24.800			24.800	24.800
<b>SubTotal</b>	<b>9,239.579</b>	<b>0.000</b>	<b>48,723.539</b>	<b>57,963.118</b>	<b>57,963.118</b>
% of investment cost	15.940	0.000	84.060	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? **NO**



# SESWater EBSD Model Run Output



Case Name: Least Cost stakeholder (WDHR)

Code: Run027

Input file to be used: EBSD Input Template SESW PR19 v4.8 WDHR.xlsx


Date/Time of optimisation run: 11:40 29<sup>nd</sup> Nov 2017

## Options Used and Start Year:


	Delivery Year	Is Option Utilised?
<b>iAOZ</b>		
SESXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-LEA-399a: Mains renewal_a	2021	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2021	<input checked="" type="checkbox"/>
SESW-MET-311: Smart metering of selected households	2046	<input checked="" type="checkbox"/>
SESW-NGW-R22: Outwood Lane	2051	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2055	<input type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2058	<input type="checkbox"/>
SESW-LEA-302b: Improve RM efficiency_b	2063	<input checked="" type="checkbox"/>
SESW-LEA-301a: Improve ALC efficiency_a	2063	<input checked="" type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2063	<input checked="" type="checkbox"/>
SESW-WEF-307: Variable infrastructure charge	2065	<input checked="" type="checkbox"/>
SESW-WEF-157: Dual flush toilets retrofit	2065	<input checked="" type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2068	<input type="checkbox"/>
SESW-LEA-073f: Increased ALC effort_f	2075	<input checked="" type="checkbox"/>
SESW-WEF-022: Non HH WEF company led self install	2075	<input checked="" type="checkbox"/>
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS DYAA   
  Bars   
  Lines   
  Capacity   
  Utilisation



Company Level     Single WRZ    PS      Bars     Lines     Capacity     Utilisation



Costs:

Display Mode:  Undiscounted     NPV    Assessment period: 2099

### Undiscounted Cost of Solution

£k     €Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	8,423.638			8,423.638	8,423.638
Fixed Opex	529.020		-10,203.733	-9,674.713	-9,674.713
Var Opex	3,523.944			3,523.944	3,523.944
Co2 Capex	0.981		0.005	0.986	0.986
Co2 Opex			-0.000	-0.000	-0.000
E&S Capex	0.017			0.017	0.017
E&S Opex	23.898			23.898	23.898
<b>SubTotal</b>	<b>12,501.498</b>	<b>0.000</b>	<b>-10,203.728</b>	<b>2,297.771</b>	<b>2,297.771</b>
% of investment cost	544.071	0.000	-444.071	100.000	
Existing WAFU Sources		Existing WAFU Bulk Imports	Existing Transfers	Deficit Options	
		0.000			

Are there any deficit options selected or used?    NO



# SESWater EBSD Model Run Output



Case Name: Least Cost without mandatory options (1 in 200)

Code: Run028

Input file to be used: EBSD Input Template SESW PR19 v4.8 1 in 200.xlsx


Date/Time of optimisation run: 16:40 29<sup>nd</sup> Nov 2017

## Options Used and Start Year:

IAOZ	Delivery Year	Is Option Utilised?
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-LEA-399a: Mains renewal_a	2021	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2021	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2049	<input checked="" type="checkbox"/>
SESW-NGW-R22: Outwood Lane	2052	<input checked="" type="checkbox"/>
SESW-LEA-302a: Improve RM efficiency_a	2055	<input checked="" type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2057	<input type="checkbox"/>
SESW-LEA-301a: Improve ALC efficiency_a	2063	<input checked="" type="checkbox"/>
SESW-WEF-307: Variable infrastructure charge	2065	<input checked="" type="checkbox"/>
SESW-WEF-157: Dual flush toilets retrofit	2065	<input checked="" type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2068	<input type="checkbox"/>
SESW-WEF-022: Non HH WEF company led self install	2075	<input checked="" type="checkbox"/>
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS DYAA   
  Bars   
  Lines   
  Capacity   
  Utilisation




Company Level  Single WRZ

PS DYCP

Bars  Lines

Capacity  Utilisation



Costs:

Display Mode:  Undiscounted  NPV

Assessment period: 2099

Undiscounted Cost of Solution (€k)

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	8,514.552			8,514.552	8,514.552
Fixed Opex	539.340		-13,713.186	-13,173.846	-13,173.846
Var Opex	3,823.023			3,823.023	3,823.023
Co2 Capex	0.981		0.005	0.986	0.986
Co2 Opex			-0.000	-0.000	-0.000
E&S Capex	0.017			0.017	0.017
E&S Opex	25.296			25.296	25.296
<b>SubTotal</b>	<b>12,903.209</b>	<b>0.000</b>	<b>-13,713.182</b>	<b>-809.973</b>	<b>-809.973</b>
% of investment cost	-1,593.042	0.000	1,693.042	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? **NO**



# SESWater EBSD Model Run Output



Case Name: Environmental run stakeholder (WDHR)

Code: Run029

Input file to be used: EBSD Input Template SESW PR19 v4.8 WDHR.xlsx


Date/Time of optimisation run: 15:40 29<sup>nd</sup> Nov 2017


## Options Used and Start Year:

iAOZ	Delivery Year	Is Option Utilised?
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-LEA-399a: Mains renewal_a	2021	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2021	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2050	<input checked="" type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2053	<input type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2059	<input type="checkbox"/>
SESW-WEF-022: Non HH WEF company led self install	2064	<input checked="" type="checkbox"/>
SESW-LEA-301a: Improve ALC efficiency_a	2065	<input checked="" type="checkbox"/>
SESW-LEA-073g: Increased ALC effort_g	2065	<input checked="" type="checkbox"/>
SESW-WEF-157: Dual flush toilets retrofit	2065	<input checked="" type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESW-LEA-073c: Increased ALC effort_c	2067	<input checked="" type="checkbox"/>
SESW-LEA-073f: Increased ALC effort_f	2075	<input checked="" type="checkbox"/>
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>
SESW-LEA-302a: Improve RM efficiency_a	2077	<input checked="" type="checkbox"/>

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS    
 Bars   
 Lines   
 Capacity   
 Utilisation





Costs:

Display Mode:  Undiscounted     NPV    Assessment period: 2099

### Undiscounted Cost of Solution

£k     £Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	10,128.807			10,128.807	10,128.807
Fixed Opex	355.200		-2,615.478	-2,260.278	-2,260.278
Var Opex	108.001			108.001	108.001
Co2 Capex	0.961		0.003	0.965	0.965
Co2 Opex			0.000	0.000	0.000
E&S Capex	0.014			0.014	0.014
E&S Opex	27.600			27.600	27.600
<b>SubTotal</b>	<b>10,620.584</b>	<b>0.000</b>	<b>-2,615.475</b>	<b>8,005.109</b>	<b>8,005.109</b>
% of investment cost	132.673	0.000	-32.673	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? **NO**



# SESWater EBSD Model Run Output



Case Name: Environmental Run stakeholder (1 in 200)

Code: Run030

Input file to be used: EBSD Input Template SESW PR19 v4.8 1 in 200.xlsx


Date/Time of optimisation run: 12:40 29<sup>nd</sup> Nov 2017

## Options Used and Start Year:

IAOZ	Delivery Year	Is Option Utilised?
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-LEA-399a: Mains renewal_a	2021	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2021	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2049	<input checked="" type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2052	<input type="checkbox"/>
SESW-LEA-302a: Improve RM efficiency_a	2057	<input checked="" type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2059	<input type="checkbox"/>
SESW-WEF-307: Variable infrastructure charge	2065	<input checked="" type="checkbox"/>
SESW-WEF-157: Dual flush toilets retrofit	2065	<input checked="" type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESW-LEA-073g: Increased ALC effort_g	2066	<input checked="" type="checkbox"/>
SESW-LEA-301a: Improve ALC efficiency_a	2068	<input checked="" type="checkbox"/>
SESW-LEA-073f: Increased ALC effort_f	2075	<input checked="" type="checkbox"/>

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS DYAA   
  Bars   
  Lines   
  Capacity   
  Utilisation




Company Level  Single WRZ

PS DYCP

Bars  Lines

Capacity  Utilisation



Costs:

Display Mode:  Undiscounted  NPV

Assessment period: 2099

Undiscounted Cost of Solution  £k  £Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	10,214.812			10,214.812	10,214.812
Fixed Opex	360.100		-7,017.867	-6,657.767	-6,657.767
Var Opex	143.926			143.926	143.926
Co2 Capex	0.961		0.004	0.965	0.965
Co2 Opex			-0.000	-0.000	-0.000
E&S Capex	0.014			0.014	0.014
E&S Opex	28.000			28.000	28.000
<b>SubTotal</b>	<b>10,747.814</b>	<b>0.000</b>	<b>-7,017.864</b>	<b>3,729.950</b>	<b>3,729.950</b>
% of investment cost	288.149	0.000	-188.149	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? **NO**



# SESWater EBSD Model Run Output



Case Name: Improved Level of Service Cost stakeholder (WDHR)

Code: Run031

Input file to be used: EBSD Input Template SESW PR19 v4.8 WDHR.xlsx


Date/Time of optimisation run: 15:40 29<sup>nd</sup> Nov 2017


## Options Used and Start Year:

IAOZ	Delivery Year	Is Option Utilised?
SESW-EXW-WAF1 : Existing WAFU Sources	2020	✓
SESW-LEA-399a: Mains renewal_a	2021	✓
SESW-LEA-303: Enhanced pressure management	2021	✓
SESW-NGW-R22: Outwood Lane	2042	✓
SESW-WEF-022: Non HH WEFF company led self install	2044	✓
SESW-MET-311: Smart metering of selected households	2045	✓
SESW-NGW-N4: Leatherhead licence increase	2046	✓
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2049	✓
SESW-LEA-302c: Improve RM efficiency_c	2053	✓
SESW-LEA-301b: Improve ALC efficiency_b	2054	✓
SESW-LEA-073f: Increased ALC effort_f	2055	✓
SESW-WEF-307: Variable infrastructure charge	2058	✓
SESW-NGW-N5: New Lower Mole Abstraction source	2060	✓
SESW-LEA-073g: Increased ALC effort_g	2064	✓
SESW-LEA-073c: Increased ALC effort_c	2065	✓
SESW-WEF-157: Dual flush toilets retrofit	2065	✓
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	✓
SESW-NGW-R28: Lowering pumps at Kenley and Purley	2074	☐
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	✓

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS DYAA   
  Bars   
  Lines   
  Capacity   
  Utilisation





Costs:

Display Mode:  Undiscounted     NPV    Assessment period: 2099

Undiscounted Cost of Solution     £k     £Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	12,596.829			12,596.829	12,596.829
Fixed Opex	1,727.980		2,845.719	4,573.699	4,573.699
Var Opex	8,653.784			8,653.784	8,653.784
Co2 Capex	1.074		0.005	1.079	1.079
Co2 Opex			0.000	0.000	0.000
E&S Capex	0.295			0.295	0.295
E&S Opex	29.168			29.168	29.168
<b>SubTotal</b>	<b>23,009.130</b>	<b>0.000</b>	<b>2,845.725</b>	<b>25,854.855</b>	<b>25,854.855</b>
% of investment cost	88.993	0.000	11.007	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? **NO**



# SESWater EBSD Model Run Output



Case Name: Improved Level of Service Run stakeholder (1 in 200)

Code: Run032

Input file used: EBSD Input Template EBSD Input Template SESW PR19 v4.8 1 in 200.xlsx


Date/Time of optimisation run: 12:40 30<sup>nd</sup> Nov 2017


## Options Used and Start Year:

IAOZ	Delivery Year	Is Option Utilised?
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-LEA-399a: Mains renewal_a	2021	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2021	<input checked="" type="checkbox"/>
SESW-NGW-R22: Outwood Lane	2040	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2044	<input checked="" type="checkbox"/>
SESW-MET-311: Smart metering of selected households	2046	<input checked="" type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2047	<input checked="" type="checkbox"/>
SESW-LEA-301a: Improve ALC efficiency_a	2051	<input checked="" type="checkbox"/>
SESW-LEA-302c: Improve RM efficiency_c	2054	<input checked="" type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2056	<input checked="" type="checkbox"/>
SESW-LEA-073g: Increased ALC effort_g	2062	<input checked="" type="checkbox"/>
SESW-LEA-073f: Increased ALC effort_f	2062	<input checked="" type="checkbox"/>
SESW-WEF-307: Variable infrastructure charge	2065	<input checked="" type="checkbox"/>
SESW-WEF-157: Dual flush toilets retrofit	2065	<input checked="" type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESW-NGW-R28: Lowering pumps at Kenley and Purley	2072	<input type="checkbox"/>
SESW-WEF-022: Non HH WEF company led self install	2075	<input checked="" type="checkbox"/>
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>

## Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS DYAA   
  Bars   
  Lines   
  Capacity   
  Utilisation





### Costs:

Display Mode:  Undiscounted     NPV

Assessment period: 2099

Undiscounted Cost of Solution     £k     £Mll

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	13,534.067			13,534.067	13,534.067
Fixed Opex	1,842.420		-3,617.372	-1,774.952	-1,774.952
Var Opex	10,309.408			10,309.408	10,309.408
Co2 Capex	1.074		0.005	1.079	1.079
Co2 Opex			-0.000	-0.000	-0.000
E&S Capex	0.295			0.295	0.295
E&S Opex	30.776			30.776	30.776
<b>SubTotal</b>	<b>25,718.041</b>	<b>0.000</b>	<b>-3,617.367</b>	<b>22,100.674</b>	<b>22,100.674</b>
% of investment cost	116.368	0.000	-16.368	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? **NO**



## SESWater EBSD Model Run Output



Case Name: Stakeholder runs with Met555 + 2035 export w/o R22/R28 (WDHR) starting at 2020

Code: Run041

Input file to be used: EBSD Input Template SESW PR19 v4.10 WDHR.xlsx


Date/Time of Optimisation run: 16:50 23<sup>th</sup> Jan 2018

### Options Used and Start Year:

iAOZ	Delivery Year	Is Option Utilised?
SESW-MET-555: Compulsory smart metering - higher meter penetration	2020	<input checked="" type="checkbox"/>
SESW-LEA-399d: Mains renewal_d	2020	<input checked="" type="checkbox"/>
SESW-LEA-303: Enhanced pressure management	2020	<input checked="" type="checkbox"/>
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-NGW-N4: Leatherhead licence increase	2054	<input checked="" type="checkbox"/>
SESW-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2057	<input type="checkbox"/>
SESW-NGW-N5: New Lower Mole Abstraction source	2063	<input type="checkbox"/>
SESW-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESW-WEF-307: Variable infrastructure charge	2069	<input checked="" type="checkbox"/>
SESW-WEF-157: Dual flush toilets retrofit	2069	<input checked="" type="checkbox"/>
SESW-LEA-302c: Improve RM efficiency_c	2070	<input checked="" type="checkbox"/>
SESW-LEA-301a: Improve ALC efficiency_a	2071	<input checked="" type="checkbox"/>
SESW-RTR-N8: Pipeline linking Pains Hill, Duckpit Wood and Chalk Pit Lane to existing treatment works at Westwood and Godstone	2074	<input type="checkbox"/>
SESW-WEF-022: Non HH WEFF company led self install	2075	<input checked="" type="checkbox"/>
SESW-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>

### Supply/Demand Balance:

Company Level   
  Single WRZ   
 PS DYAA   
  Bars   
  Lines   
  Capacity   
  Utilisation




Company Level  Single WRZ

PS DYCP

Bars  Lines

Capacity  Utilisation



Costs:

Display Mode:  Undiscounted  NPV

Assessment period: 2099

Undiscounted Cost of Solution

Units:  £k  £Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	12,951.157			12,951.157	12,951.157
Fixed Opex	1,573.300		76,499.580	78,072.880	78,072.880
Var Opex	2,044.103			2,044.103	2,044.103
Co2 Capex	4.278		0.008	4.286	4.286
Co2 Opex			-0.003	-0.003	-0.003
E&S Capex	0.555			0.555	0.555
E&S Opex	25.988			25.988	25.988
<b>SubTotal</b>	<b>16,599.382</b>	<b>0.000</b>	<b>76,499.585</b>	<b>93,098.967</b>	<b>93,098.967</b>
% of investment cost	17.830	0.000	82.170	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? NO



# SESWater EBSD Model Run Output



Case Name: Final Run with N8 1in200

Code: Run043

Input file to be used: EBSD Input Template SESW PR19 v4.11 1in200.xlsx


Date/Time of Optimisation run: 18:15 23<sup>th</sup> Jan 2018

## Options Used and Start Year:


	Delivery Year	Is Option Utilised?
<b>iGOP</b>		
SESU-MET-555: Compulsory smart metering - higher meter penetration	2020	<input checked="" type="checkbox"/>
SESU-LEA-399d: Mains renewal_d	2020	<input checked="" type="checkbox"/>
SESU-LEA-303: Enhanced pressure management	2020	<input checked="" type="checkbox"/>
SESU-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESU-NGW-N4: Leatherhead licence increase	2053	<input type="checkbox"/>
SESU-NGW-R5: New borehole (Mole Valley Chalk) - Fetcham Springs	2056	<input type="checkbox"/>
SESU-LEA-302c: Improve RM efficiency_c	2057	<input checked="" type="checkbox"/>
SESU-NGW-N5: New Lower Mole Abstraction source	2064	<input type="checkbox"/>
SESU-WEF-307: Variable infrastructure charge	2065	<input checked="" type="checkbox"/>
SESU-WEF-308: Campaign targeting domestic customers with high consumption - leaking toilets	2065	<input checked="" type="checkbox"/>
SESU-LEA-073f: Increased ALC effort_f	2073	<input checked="" type="checkbox"/>
SESU-WEF-022: Non HH WEFF company led self install	2075	<input checked="" type="checkbox"/>
SESU-WEF-021: Household WEFF programme partnering approach home visit	2075	<input checked="" type="checkbox"/>
SESU-WEF-305: Domestic retrofit targeting high consumers	2075	<input checked="" type="checkbox"/>
SESU-RTR-N8: Pipeline linking Pains Hill, Duckpit Wood and Chalk Pit Lane to existing treatment works at Westwood and Godstone	2078	<input type="checkbox"/>

## Supply/Demand Balance:

DYAA



# DYCP



## Costs:

Display Mode:  Undiscounted  NPV

Assessment period: 2099

Undiscounted Cost of Solution  £k  £Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex	12,310.366			12,310.366	12,310.366
Fixed Opex	1,383.100		79,567.378	80,950.478	80,950.478
Var Opex	0.903			0.903	0.903
Co2 Capex	4.278		0.007	4.285	4.285
Co2 Opex	0.000		-0.003	-0.003	-0.003
E&S Capex	0.555			0.555	0.555
E&S Opex	26.067			26.067	26.067
<b>SubTotal</b>	<b>13,725.269</b>	<b>0.000</b>	<b>79,567.382</b>	<b>93,292.651</b>	<b>93,292.651</b>
% of investment cost	14.712	0.000	85.288	100.000	
Existing WAFU Sources	Existing WAFU Bulk Imports	Existing Transfers	Deficit Options		
	0.000				

Are there any deficit options selected or used? **NO**



# SESWater EBSD Model Run Output



Case Name: Business Plan Run 5, weighted towards MET (WDHR)

Code: RunF05

Input file to be used: EBSD Input Template SESW PR19 v5 WDHR run2.xlsx

Date/Time of Optimisation run: 3:15 pm 5<sup>th</sup> July 2018


Options Used and Start Year:

	Delivery Year	Is Option Utilised?
IAOZ		
SESW-LEA-900: Leakage bundle 1	2020	<input checked="" type="checkbox"/>
SESW-WEF-700b-ph1: PR19 Option 1b (phase 1)	2020	<input checked="" type="checkbox"/>
SESW-MET-600: Compulsory metering AMI - enhanced higher meter penetration	2020	<input checked="" type="checkbox"/>
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-TAR-800b: Tariffs (scenario b)	2045	<input checked="" type="checkbox"/>
SESW-WEF-700b-ph2: PR19 Option 1b(phase 1)	2045	<input checked="" type="checkbox"/>


Supply/Demand Balance:

DYAA

Company Level     Single WRZ    PS DYAA     Bars     Lines     Capacity     Utilisation



# DYCP



## Costs:

**Undiscounted Cost of Solution**     £k     £Mill

**Display Mode:**  Undiscounted     NPV

**Assessment period:** 2099

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex					
Fixed Opex			169,512.914	169,512.914	169,512.914
Var Opex					0.000
Co2 Capex			0.025	0.025	0.025
Co2 Opex			-0.152	-0.152	-0.152
E&S Capex					
E&S Opex					
<b>SubTotal</b>	<b>0.000</b>	<b>0.000</b>	<b>169,512.786</b>	<b>169,512.786</b>	<b>169,512.786</b>
% of investment cost	0.000	0.000	100.000	100.000	
Existing WAFU Sources					
Existing WAFU Bulk Imports	0.000				
Existing Transfers					
Deficit Options					

Are there any deficit options selected or used? **NO**



Case Name: Business Plan Run 6, weighted towards MET (1in200)

Code: RunF06

Input file to be used: EBSD Input Template SESW PR19 v5 1in200 run2.xlsx

Date/Time of Optimisation run: 3:45 pm 29<sup>th</sup> June 2018


Options Used and Start Year:

	Delivery Year	Is Option Utilised?
IAOZ		
SESW-LEA-900: Leakage bundle 1	2020	<input checked="" type="checkbox"/>
SESW-WEF-700b-ph1: PR19 Option 1b (phase 1)	2020	<input checked="" type="checkbox"/>
SESW-MET-600: Compulsory metering AMI - enhanced higher meter penetration	2020	<input checked="" type="checkbox"/>
SESW-EXW-WAF1 : Existing WAFU Sources	2020	<input checked="" type="checkbox"/>
SESW-TAR-800b: Tariffs (scenario b)	2045	<input checked="" type="checkbox"/>
SESW-WEF-700b-ph2: PR19 Option 1b(phase 1)	2045	<input checked="" type="checkbox"/>

Supply/Demand Balance:


DYAA

Company Level     Single WRZ    PS DYAA     Bars     Lines     Capacity     Utilisation



# DYCP

Company Level     Single WRZ    PS **DYCP**     Bars     Lines     Capacity     Utilisation



## Costs:

Display Mode:  Undiscounted     NPV

Assessment period: 2099

Undiscounted Cost of Solution     £k     €Mill

	New Water Options	New Transfer Options	Demand Management Options	Investment SubTotal	Undiscounted Total (incl. Ex WAFU, Ex bulk imports & Ex Transfers Vopex)
Capex					
Fixed Opex			169,512.914	169,512.914	169,512.914
Var Opex					0.000
Co2 Capex			0.025	0.025	0.025
Co2 Opex			-0.152	-0.152	-0.152
E&S Capex					
E&S Opex					
SubTotal	0.000	0.000	169,512.786	169,512.786	169,512.786
% of investment cost	0.000	0.000	100.000	100.000	
Existing WAFU Sources	0.000				
Existing WAFU Bulk Imports					
Existing Transfers					
Deficit Options					

Are there any deficit options selected or used? **NO**

